

Supplemental/Bid Bulletin
Addendum No. 1

TITLE : Right Sizing of Electrical Wires in Home for Girls (PSCB Building) and Reception and Study Center for Children
ITB NO. : DSWD7-PB-2024-60
DATE : 19 November 2024

Issued pursuant to Section 22.5 of the IRR of Republic Act 9184 to clarify and/or anent certain provision on the Bidding Documents issued for this project, considering the issues raised and clarifications made by prospective bidders during the Pre-bid Conference held on **November 08, 2024**, and shall form an integral part thereof, viz:

Subject	Amendment/Agreement/Clarification
Section VIII. Bill of Quantities	<ul style="list-style-type: none">➤ This supplemental / bid bulletin is issued to update the Bill of Quantities:<ul style="list-style-type: none">○ 3.2 Wires and Wiring Devices<ul style="list-style-type: none">HFG - Admin Building to PSCB, Single Phase (250mm² THHN Wire stranded with 80mm² THHN Wire ground) and<ul style="list-style-type: none">- Groundfloor panel board to Second floor panel board, (80mm² THHN Wire stranded with 30mm² THHN Wire ground).RSCC- Single Phase (200mm² THHN Wire stranded with 80mm² THHN Wire ground),<ul style="list-style-type: none">- solderless connector- Stainless steel U Clamp- Megger Testing before and after tapping- Testing and commissioning

Attached herewith is the **Revised Section VIII. Bill of Quantities**.

This Bid Bulletin shall form part of the bidding documents.

Please be guided accordingly.


ROSEMARIE S. SALAZAR
Chairperson, Bids and Awards Committee I

Revised Section VIII. Bill of Quantities

Right Sizing of Electrical Wires in Home for Girls (PSCB Building) and Reception and Study Center for Children					
ITEM NO.	DESCRIPTION	QUANTITY	UNIT	UNIT COST	TOTAL COST
1. GENERAL REQUIREMENTS					
1.1	Excavation of Ground and backfilling	1	L.S.		
SUB-TOTAL (1. GENERAL REQUIREMENTS)					
1. FINISHING					
2.1	Raceway and Brackets	1.00	lot		
2.2	Reinforcing Steel (Deformed, Grade 40)	50.00	kg.		
2.3	Structural Concrete (Class A, 28 days)	0.85	cu.m.		
2.4	Painting Works (Pipes, Brackets)	20.00	sq.m.		
SUB-TOTAL (2. FINISHING)					
3. ELECTRICAL & ELECTRONICS					
3.1	Conduits, Boxes and Fittings Electrical PVC (Heavy Duty) -90mmØ PVC Electrical Pipe, 90mmØ PVC Elbow, PVC Solvent 400cc	1	L.S.		
3.2	Wires and Wiring Devices, HFG - Admin Building to PSCB, Single Phase (250mm ² THHN Wire stranded with 80mm ² THHN Wire ground) and - Groundfloor panel board to Second floor panel board, (80mm ² THHN Wire stranded with 30mm ² THHN Wire ground). RSCC- Single Phase (200mm ² THHN Wire stranded with 80mm ² THHN Wire ground), - solderless connector - Stainless steel U Clamp - Megger Testing before and after tapping - Testing and commissioning	1	L.S.		
SUB-TOTAL (3. ELECTRICAL & ELECTRONICS)					
TOTAL BID COST					

NOTE: Only TWO (2) decimal places will be considered. (General Rules in rounding-off decimals: If the digit to the right of the rounding number is greater than or equal to 5, you have to round up or add 1 to the rounded digit and drop all the digits to its right [Lumbre, A. P. and Ursua, A. C. (2016). 21st Century Mathletes 5 textbook. Quezon City: Vibal Group, Inc.])