

DEPARTMENT OF SOCIAL WELFARE AND DEVELOPMENT

FIELD OFFICE VII

CEBU CITY

BIDDING DOCUMENTS FOR

**Repair and Improvement of Center and
Residential Care Facilities (CRCF) of DSWD
Field Office VII in Labangon, Cebu City**

ITB No. DSWD7-PB-2022-54

July 2022

TABLE OF CONTENTS

SECTION I. INVITATION TO BID	4
SECTION II. INSTRUCTIONS TO BIDDERS	7
1. Scope of Bid.....	8
2. Funding Information	8
3. Bidding Requirements.....	8
4. Corrupt, Fraudulent, Collusive, Coercive, and Obstructive Practices	9
5. Eligible Bidders.....	9
6. Origin of Associated Goods	9
7. Subcontracts	10
8. Pre-Bid Conference.....	10
9. Clarification and Amendment of Bidding Documents.....	10
10. Documents Comprising the Bid: Eligibility and Technical Components	10
11. Documents Comprising the Bid: Financial Component	11
12. Alternative Bids	11
13. Bid Prices	11
14. Bid and Payment Currencies.....	11
15. Bid Security.....	12
16. Sealing and Marking of Bids.....	12
17. Deadline for Submission of Bids	12
18. Opening and Preliminary Examination of Bids	12
19. Detailed Evaluation and Comparison of Bids.....	12
20. Post Qualification.....	13
21. Signing of the Contract	13
SECTION III. BID DATA SHEET.....	14
SECTION IV. GENERAL CONDITIONS OF CONTRACT.....	17
1. Scope of Contract.....	17
2. Sectional Completion of Works	17
3. Possession of Site	17
4. The Contractor's Obligations.....	18
5. Performance Security	18
6. Site Investigation Reports	18

7.	Warranty.....	18
8.	Liability of the Contractor.....	18
9.	Termination for Other Causes.....	19
10.	Dayworks	19
11.	Program of Work.....	19
12.	Instructions, Inspections and Audits	19
13.	Advance Payment.....	19
14.	Progress Payments	20
15.	Operating and Maintenance Manuals.....	20
SECTION V. SPECIAL CONDITIONS OF CONTRACT		21
SECTION VI. SPECIFICATIONS		22
SECTION VII. DRAWINGS		40
SECTION VIII. BILL OF QUANTITIES		64
SECTION IX. CHECKLIST OF TECHNICAL AND FINANCIAL DOCUMENTS.....		73
SECTION X. BIDDING FORMS		76
BID FORM.....		80

Section I. Invitation to Bid

Project Title: Repair of Improvement of Center and Residential Care Facilities (CRCF) of DSWD Field Office VII in Labangon, Cebu City

Project Identification No.: ITB No. DSWD7-PB-2022-54

- The *Department of Social Welfare and Development Field Office VII (DSWD-FO VII)*, through the *authorized appropriations for Fiscal Year 2022 General Appropriations Act* intends to apply the sum of ***Twelve Million Two Hundred Sixteen Thousand Nine Hundred Pesos Only (₱12,216,900.00)*** being the Approved Budget for the Contract (ABC) to payments under the contract for the ***Repair and Improvement of Center and Residential Care Facilities (CRCF) of DSWD Field Office VII in Labangon, Cebu City***, consisting of two (2) lots, broken down below:

Lot No.	Project Title	ABC
1	Repair of AVRC II Wing I, Wing III, Wing IV Roofing, Ceiling and Room Partitions	Php 9,187,000.00
2	Repair of AVRC II Covered Court Roofing, Ceiling and Stage Wall	Php 1,040,000.00
3	Repair of Regional Haven for Women Admin Building Roofing, Flooring, Old Dormitory Main Door, Improvement of Ventilation and Concreting of Ramp	Php 1,089,000.00
4	Repair of HFG Covered Court Roofing, Ceiling and PSCB Building Storage Door and Main Door	Php 900,900.00
<i>TOTAL</i>		<i>Php 12,216,900.00</i>

Bids received in excess of the ABC shall be automatically rejected at bid opening.

- The *DSWD Field Office VII* now invites bids from ***PhilGEPS registered service provider***. Completion of the Work is required within the following period:

Lot No.	Project Title	Completion of Work
1	Repair of AVRC II Wing I, Wing III, Wing IV Roofing, Ceiling and Room Partitions	<i>90 calendar days from receipt of Notice to Proceed</i>

Lot No.	Project Title	Completion of Work
2	Repair of AVRC II Covered Court Roofing, Ceiling and Stage Wall	<i>90 calendar days from receipt of Notice to Proceed</i>
3	Repair of Regional Haven for Women Admin Building Roofing, Flooring, Old Dormitory Main Door, Improvement of Ventilation and Concreting of Ramp	
4	Repair of HFG Covered Court Roofing, Ceiling and PSCB Building Storage Door and Main Door	
TOTAL		Php 12,216,900.00

Bidders should have completed a contract similar to the project. A **single largest completed contract (SLCC)** similar to the Project which is equivalent to **at least 50% of the ABC**. Details are as follows:

Lot No.	Project Title	SLCC (50% of ABC)
1	Repair of AVRC II Wing I, Wing III, Wing IV Roofing, Ceiling and Room Partitions	Php 4,593,500.00
2	Repair of AVRC II Covered Court Roofing, Ceiling and Stage Wall	Php 520,000.00
3	Repair of Regional Haven for Women Admin Building Roofing, Flooring, Old Dormitory Main Door, Improvement of Ventilation and Concreting of Ramp	Php 544,500.00
4	Repair of HFG Covered Court Roofing, Ceiling and PSCB Building Storage Door and Main Door	Php 450,450.00
TOTAL		Php 6,108,450.00

The SLCC should be supported with the following documents:

- i.) Either of **Contract, Purchase Order, Notice of Award or Notice to Proceed**, and;
- ii.) Either of **Certificate of Completion, Certificate of Acceptance, Inspection and Acceptance, Official Receipt / Collection Receipt or Sales Invoice**.

The description of an eligible bidder is contained in the Bidding Documents, particularly, in Section II. Instructions to Bidders.

3. Bidding will be conducted through open competitive bidding procedures using non-discretionary “*pass/fail*” criterion as specified in the 2016 revised Implementing Rules and Regulations (IRR) of Republic Act (RA) No. 9184.

4. Interested bidders may obtain further information from *Department of Social Welfare and Development Field Office VII* and inspect the Bidding Documents at the address given below during office hours, 8:00AM – 5:00PM.
5. A complete set of Bidding Documents may be acquired by interested bidders on **July 15, 2022** from given address and website/s below *and upon payment of the applicable fee for the Bidding Documents, pursuant to the latest Guidelines issued by the GPPB, in the amount of:*

<i>Approved Budget for the Contract</i>		<i>Bidding Document Fee</i>
Lot 1	Php 9,187,000.00	Php 10,000.00
Lot 2	Php 1,040,000.00	Php 5,000.00
Lot 3	Php 1,089,000.00	Php 5,000.00
Lot 4	Php 900,900.00	Php 5,000.00
<i>ALL LOTS</i>	<i>Php 12,216,900.00</i>	<i>Php 15,000.00</i>

The Procuring Entity shall allow the bidder to present its proof of payment for the fees, they may present in person or through electronic means.

It may also be downloaded free of charge from the website of the Philippine Government Electronic Procurement System (PhilGEPS) and the website of the Procuring Entity, provided that Bidders shall pay the applicable fee for the Bidding Documents not later than the submission of their bids.

As stated in GPPB Resolution No. 09-2020, dated 7 May 2020, PEs to maximize the use of existing rules under RA No. 9184, its IRR and related issuances on the conduct of procurement activities, particularly those meant to streamline, simplify and expedite the conduct of procurement and address the challenges and disruptions brought by calamities and crisis such as the COVID-19 pandemic, such as use of videoconferencing, webcasting and similar technology in the conduct of any of the meetings and determination of quorum by the BAC.

6. The *DSWD Field Office VII* will hold a Pre-Bid Conference on **July 22, 2022, Friday, 9:00 AM at DSWD Field Office VII Conference Room, Cebu City** and/or through ***video-conferencing via Google Meet using the code: procurement7***, which shall be open to prospective bidders.

Note:

DSWD Field Office is implementing health screening and temperature check for all personnel, visitors and client. For your protection, please wear your mask and face shield at all times during your visit. Also, kindly fill-out the Health Checklist Form for visitors / clients and submit to the PE's security guard prior to entering the premise.

7. Bids must be duly received by the BAC Secretariat through manual submission at the office address as indicated below, on or before **August 3, 2022, Wednesday, 8:45 AM**. Late bids shall not be accepted.
8. All bids must be accompanied by a bid security in any of the acceptable forms and in the amount stated in **ITB** Clause 15.
9. Bid opening shall be on **August 3, 2022, Wednesday, 9:00 AM** at **DSWD Field Office VII Conference Room, Cebu City** and/or **via Google Meet using the code: procurement7**. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity.
10. As stated in Section 22.5.1 of the IRR of RA 9184, request for clarifications on any part of the Bidding Documents or for an interpretation must be in writing and submitted to the BAC of the Procuring Entity concerned at least ten (10) calendar days before the deadline set for the submission and receipt of bids. The BAC shall respond to the said request by issuing a Supplemental/Bid Bulletin, duly signed by the BAC Chairperson, to be made available to all those who have properly secured the Bidding Documents, at least seven (7) calendar days before the deadline for the submission and receipt of bids.
11. The **DSWD Field Office VII** reserves the right to reject any and all bids, declare a failure of bidding, or not award the contract at any time prior to contract award in accordance with Sections 35.6 and 41 of the 2016 revised Implementing Rules and Regulations (IRR) of RA No. 9184, without thereby incurring any liability to the affected bidder or bidders.
12. For further information, please refer to:

MS. ROSEMARIE S. SALAZAR

Head, BAC Secretariat

DSWD – Field Office VII

M.J. Cuenco corner Gen. Maxilom Avenue, Cebu City

*Tel. Nos. (032) 233-8785 local **17140** or **17149***

*Email Add: **bac.fo7@dswd.gov.ph***

*Website: **<https://fo7.dswd.gov.ph/>***

July 14, 2022



GRAEME FERDINAND D. ARMECIN
Chairperson, Bids and Awards Committee I

Section II. Instructions to Bidders

1. Scope of Bid

The Procuring Entity, *Department of Social Welfare and Development Field Office VII* invites Bids for the ***Repair and Improvement Center and Residential Care Facilities (CRCF) of DSWD Field Office VII in Labangon, Cebu City***, with Project Identification Number ***ITB No. DSWD7-PB-2022-54***.

The Procurement Project (referred to herein as “Project”) is for the construction of Works, as described in Section VI (Specifications).

2. Funding Information

- 2.1. The GOP through the source of funding as indicated below for *CY 2021* in the amount of ***Twelve Million Two Hundred Sixteen Thousand Nine Hundred Pesos Only (₱ 12,216,900.00)***, consisting of four (4) lots, broken as follows:

Lot No.	Project Title	ABC
1	Repair of AVRC II Wing I, Wing III, Wing IV Roofing, Ceiling and Room Partitions	Php 9,187,000.00
2	Repair of AVRC II Covered Court Roofing, Ceiling and Stage Wall	Php 1,040,000.00
3	Repair of Regional Haven for Women Admin Building Roofing, Flooring, Old Dormitory Main Door, Improvement of Ventilation and Concreting of Ramp	Php 1,089,000.00
4	Repair of HFG Covered Court Roofing, Ceiling and PSCB Building Storage Door and Main Door	Php 900,900.00
<i>TOTAL</i>		<i>Php 12,216,900.00</i>

- 2.2. The source of funding is NGA, the General Appropriations Act or Special Appropriations.

3. Bidding Requirements

The Bidding for the Project shall be governed by all the provisions of RA No. 9184 and its 2016 revised IRR, including its Generic Procurement Manual and associated policies, rules and regulations as the primary source thereof, while the herein clauses shall serve as the secondary source thereof.

Any amendments made to the IRR and other GPPB issuances shall be applicable only to the ongoing posting, advertisement, or invitation to bid by the BAC through the issuance of a supplemental or bid bulletin.

The Bidder, by the act of submitting its Bid, shall be deemed to have inspected the site, determined the general characteristics of the contracted Works and the conditions for this Project, such as the location and the nature of the work; (b) climatic conditions; (c) transportation facilities; (c) nature and condition of the terrain, geological conditions at the site communication facilities, requirements, location and availability of construction aggregates and other materials, labor, water, electric power and access roads; and (d) other factors that may affect the cost, duration and execution or implementation of the contract, project, or work and examine all instructions, forms, terms, and project requirements in the Bidding Documents.

4. Corrupt, Fraudulent, Collusive, Coercive, and Obstructive Practices

The Procuring Entity, as well as the Bidders and Contractors, shall observe the highest standard of ethics during the procurement and execution of the contract. They or through an agent shall not engage in corrupt, fraudulent, collusive, coercive, and obstructive practices defined under Annex “I” of the 2016 revised IRR of RA No. 9184 or other integrity violations in competing for the Project.

5. Eligible Bidders

5.1. Only Bids of Bidders found to be legally, technically, and financially capable will be evaluated.

5.2. The Bidder must have an experience of having completed a Single Largest Completed Contract (SLCC) that is similar to this Project, equivalent to at least fifty percent (50%) of the ABC adjusted, if necessary, by the Bidder to current prices using the PSA’s CPI, except under conditions provided for in Section 23.4.2.4 of the 2016 revised IRR of RA No. 9184.

A contract is considered to be “similar” to the contract to be bid if it has the major categories of work stated in the **BDS**.

5.3. For Foreign-funded Procurement, the Procuring Entity and the foreign government/foreign or international financing institution may agree on another track record requirement, as specified in the Bidding Document prepared for this purpose.

5.4. The Bidders shall comply with the eligibility criteria under Section 23.4.2 of the 2016 IRR of RA No. 9184.

6. Origin of Associated Goods

There is no restriction on the origin of Goods other than those prohibited by a decision of the UN Security Council taken under Chapter VII of the Charter of the UN.

7. Subcontracts

- 7.1. The Bidder may subcontract portions of the Project to the extent allowed by the Procuring Entity as stated herein, but in no case more than fifty percent (50%) of the Project.

The Procuring Entity has prescribed that *Subcontracting is not allowed*.

- 7.2. Subcontracting of any portion of the Project does not relieve the Contractor of any liability or obligation under the Contract. The Supplier will be responsible for the acts, defaults, and negligence of any subcontractor, its agents, servants, or workmen as fully as if these were the Contractor's own acts, defaults, or negligence, or those of its agents, servants, or workmen.

8. Pre-Bid Conference

The Procuring Entity will hold a pre-bid conference for this Project on the **July 22, 2022, Friday, 9:00 AM** at **DSWD Field Office VII Conference Room, Cebu City** and/or through *video-conferencing via Google Meet using the code: procurement7* as indicated in paragraph 6 of the **IB**.

9. Clarification and Amendment of Bidding Documents

Prospective bidders may request for clarification on and/or interpretation of any part of the Bidding Documents. Such requests must be in writing and received by the Procuring Entity, either at its given address or through electronic mail indicated in the **IB**, at least ten (10) calendar days before the deadline set for the submission and receipt of Bids.

10. Documents Comprising the Bid: Eligibility and Technical Components

- 10.1. The first envelope shall contain the eligibility and technical documents of the Bid as specified in **Section IX. Checklist of Technical and Financial Documents**.
- 10.2. If the eligibility requirements or statements, the bids, and all other documents for submission to the BAC are in foreign language other than English, it must be accompanied by a translation in English, which shall be authenticated by the appropriate Philippine foreign service establishment, post, or the equivalent office having jurisdiction over the foreign bidder's affairs in the Philippines. For Contracting Parties to the Apostille Convention, only the translated documents shall be authenticated through an apostille pursuant to GPPB Resolution No. 13-2019 dated 23 May 2019. The English translation shall govern, for purposes of interpretation of the bid.
- 10.3. A valid PCAB License is required, and in case of joint ventures, a valid special PCAB License, and registration for the type and cost of the contract for this Project. Any additional type of Contractor license or permit shall be indicated in the **BDS**.

- 10.4. A List of Contractor's key personnel (e.g., Project Manager, Project Engineers, Materials Engineers, and Foremen) assigned to the contract to be bid, with their complete qualification and experience data shall be provided. These key personnel must meet the required minimum years of experience set in the **BDS**.
- 10.5. A List of Contractor's major equipment units, which are owned, leased, and/or under purchase agreements, supported by proof of ownership, certification of availability of equipment from the equipment lessor/vendor for the duration of the project, as the case may be, must meet the minimum requirements for the contract set in the **BDS**.

11. Documents Comprising the Bid: Financial Component

- 11.1. The second bid envelope shall contain the financial documents for the Bid as specified in **Section IX. Checklist of Technical and Financial Documents**.
- 11.2. Any bid exceeding the ABC indicated in paragraph 1 of the **IB** shall not be accepted.
- 11.3. For Foreign-funded procurement, a ceiling may be applied to bid prices provided the conditions are met under Section 31.2 of the 2016 revised IRR of RA No. 9184.

12. Alternative Bids

Bidders shall submit offers that comply with the requirements of the Bidding Documents, including the basic technical design as indicated in the drawings and specifications. Unless there is a value engineering clause in the **BDS**, alternative Bids shall not be accepted.

13. Bid Prices

All bid prices for the given scope of work in the Project as awarded shall be considered as fixed prices, and therefore not subject to price escalation during contract implementation, except under extraordinary circumstances as determined by the NEDA and approved by the GPPB pursuant to the revised Guidelines for Contract Price Escalation guidelines.

14. Bid and Payment Currencies

- 14.1. Bid prices may be quoted in the local currency or tradeable currency accepted by the BSP at the discretion of the Bidder. However, for purposes of bid evaluation, Bids denominated in foreign currencies shall be converted to Philippine currency based on the exchange rate as published in the BSP reference rate bulletin on the day of the bid opening.
- 14.2. *Payment of the contract price shall be made in Philippine Pesos.*

15. Bid Security

- 15.1. The Bidder shall submit a Bid Securing Declaration or any form of Bid Security in the amount indicated in the **BDS**, which shall be not less than the percentage of the ABC in accordance with the schedule in the **BDS**.
- 15.2. The Bid and bid security shall be valid until **120 calendar days**. Any bid not accompanied by an acceptable bid security shall be rejected by the Procuring Entity as non-responsive.

16. Sealing and Marking of Bids

Each Bidder shall submit one copy of the first and second components of its Bid.

The Procuring Entity may request additional hard copies and/or electronic copies of the Bid. However, failure of the Bidders to comply with the said request shall not be a ground for disqualification.

If the Procuring Entity allows the submission of bids through online submission to the given website or any other electronic means, the Bidder shall submit an electronic copy of its Bid, which must be digitally signed. An electronic copy that cannot be opened or is corrupted shall be considered non-responsive and, thus, automatically disqualified.

17. Deadline for Submission of Bids

The Bidders shall submit on the specified date and time and either at its physical address or through online submission as indicated in paragraph 7 of the **IB**.

18. Opening and Preliminary Examination of Bids

- 18.1. The BAC shall open the Bids in public at the time, on the date, and at the place specified in paragraph 9 of the **IB**. The Bidders' representatives who are present shall sign a register evidencing their attendance. In case videoconferencing, webcasting or other similar technologies will be used, attendance of participants shall likewise be recorded by the BAC Secretariat.

In case the Bids cannot be opened as scheduled due to justifiable reasons, the rescheduling requirements under Section 29 of the 2016 revised IRR of RA No. 9184 shall prevail.

- 18.2. The preliminary examination of Bids shall be governed by Section 30 of the 2016 revised IRR of RA No. 9184.

19. Detailed Evaluation and Comparison of Bids

- 19.1. The Procuring Entity's BAC shall immediately conduct a detailed evaluation of all Bids rated "*passed*" using non-discretionary pass/fail criteria. The BAC

shall consider the conditions in the evaluation of Bids under Section 32.2 of 2016 revised IRR of RA No. 9184.

- 19.2. If the Project allows partial bids, all Bids and combinations of Bids as indicated in the **BDS** shall be received by the same deadline and opened and evaluated simultaneously so as to determine the Bid or combination of Bids offering the lowest calculated cost to the Procuring Entity. Bid Security as required by **ITB** Clause 16 shall be submitted for each contract (lot) separately.
- 19.3. In all cases, the NFCC computation pursuant to Section 23.4.2.6 of the 2016 revised IRR of RA No. 9184 must be sufficient for the total of the ABCs for all the lots participated in by the prospective Bidder.

20. Post Qualification

Within a non-extendible period of five (5) calendar days from receipt by the Bidder of the notice from the BAC that it submitted the Lowest Calculated Bid, the Bidder shall submit its latest income and business tax returns filed and paid through the BIR Electronic Filing and Payment System (eFPS), and other appropriate licenses and permits required by law and stated in the **BDS**.

21. Signing of the Contract

The documents required in Section 37.2 of the 2016 revised IRR of RA No. 9184 shall form part of the Contract. Additional Contract documents are indicated in the **BDS**.

Section III. Bid Data Sheet

ITB Clause																																											
5.2	For this purpose, contracts similar to the Project refer to contracts which have the same major categories of work, which shall be: REPAIR AND IMPROVEMENT / CONSTRUCTION																																										
7.1	<i>Subcontracting is not allowed.</i>																																										
10.3	<i>[Specify if another Contractor license or permit is required.]</i>																																										
10.4	<div>The key personnel must meet the required minimum years of experience set below:</div> <table><tr><th colspan="3">LOT 2: REPAIR OF AVRC II COVERED COURT, ROOFING, CEILING AND STAFE WALL</th></tr><tr><th>POSITION</th><th>EXPERIENCE (NO. OF YEARS)</th><th>GENERAL EXPERIENCE</th></tr><tr><td>Project Manager</td><td>10 years</td><td>General Construction</td></tr><tr><td>Project Engineer</td><td>5 years</td><td>General Construction</td></tr><tr><td>Site Engineer</td><td>5 years</td><td>General Construction</td></tr><tr><td>Safety Officer</td><td>5 years</td><td>General Construction / Safety Officer</td></tr><tr><td>Foreman</td><td>10 years</td><td>General Construction</td></tr></table> <table><tr><th colspan="3">LOT 3: REPAIR OF HOME FOR GIRLS (HFG) COVERED COURT ROOFING, CEILING AND PSCB BUILDING STORAGE DOOR AND MAIN DOOR</th></tr><tr><th>POSITION</th><th>EXPERIENCE (NO. OF YEARS)</th><th>GENERAL EXPERIENCE</th></tr><tr><td>Project Manager</td><td>10 years</td><td>General Construction</td></tr><tr><td>Project Engineer</td><td>5 years</td><td>General Construction</td></tr><tr><td>Site Engineer</td><td>5 years</td><td>General Construction</td></tr><tr><td>Safety Officer</td><td>5 years</td><td>General Construction / Safety Officer</td></tr><tr><td>Foreman</td><td>10 years</td><td>General Construction</td></tr></table>	LOT 2: REPAIR OF AVRC II COVERED COURT, ROOFING, CEILING AND STAFE WALL			POSITION	EXPERIENCE (NO. OF YEARS)	GENERAL EXPERIENCE	Project Manager	10 years	General Construction	Project Engineer	5 years	General Construction	Site Engineer	5 years	General Construction	Safety Officer	5 years	General Construction / Safety Officer	Foreman	10 years	General Construction	LOT 3: REPAIR OF HOME FOR GIRLS (HFG) COVERED COURT ROOFING, CEILING AND PSCB BUILDING STORAGE DOOR AND MAIN DOOR			POSITION	EXPERIENCE (NO. OF YEARS)	GENERAL EXPERIENCE	Project Manager	10 years	General Construction	Project Engineer	5 years	General Construction	Site Engineer	5 years	General Construction	Safety Officer	5 years	General Construction / Safety Officer	Foreman	10 years	General Construction
LOT 2: REPAIR OF AVRC II COVERED COURT, ROOFING, CEILING AND STAFE WALL																																											
POSITION	EXPERIENCE (NO. OF YEARS)	GENERAL EXPERIENCE																																									
Project Manager	10 years	General Construction																																									
Project Engineer	5 years	General Construction																																									
Site Engineer	5 years	General Construction																																									
Safety Officer	5 years	General Construction / Safety Officer																																									
Foreman	10 years	General Construction																																									
LOT 3: REPAIR OF HOME FOR GIRLS (HFG) COVERED COURT ROOFING, CEILING AND PSCB BUILDING STORAGE DOOR AND MAIN DOOR																																											
POSITION	EXPERIENCE (NO. OF YEARS)	GENERAL EXPERIENCE																																									
Project Manager	10 years	General Construction																																									
Project Engineer	5 years	General Construction																																									
Site Engineer	5 years	General Construction																																									
Safety Officer	5 years	General Construction / Safety Officer																																									
Foreman	10 years	General Construction																																									

10.4	The key personnel must meet the required minimum years of experience set below:		
	LOT 4: REPAIR OF REGIONAL HAVEN FOR WOMEN ADMIN BUILDING ROOFING, FLOORING, OLD DORMITORY MAIN DOOR, IMPROVEMENT OF VENTILATION AND CONCRETING OF RAMP		
	POSITION	EXPERIENCE (NO. OF YEARS)	GENERAL EXPERIENCE
	Project Manager	10 years	General Construction
	Project Engineer	5 years	General Construction
	Site Engineer	5 years	General Construction
	Safety Officer	5 years	General Construction / Safety Officer
	Foreman	10 years	General Construction
10.5	The minimum major equipment requirements are the following:		
	LOT 2: REPAIR OF AVRC II COVERED COURT, ROOFING, CEILING AND STAFF WALL		
	EQUIPMENT	CAPACITY	NO. OF UNIT
	Cargo Truck / Boom Truck	N/A	1
	Welding Machine	N/A	1
	LOT 3: REPAIR OF HOME FOR GIRLS (HFG) COVERED COURT ROOFING, CEILING AND PSCB BUILDING STORAGE DOOR AND MAIN DOOR		
	EQUIPMENT	CAPACITY	NO. OF UNIT
	Cargo Truck / Boom Truck	N/A	1
	Welding Machine	N/A	1
	LOT 4: REPAIR OF REGIONAL HAVEN FOR WOMEN ADMIN BUILDING ROOFING, FLOORING, OLD DORMITORY MAIN DOOR, IMPROVEMENT OF VENTILATION AND CONCRETING OF RAMP		
	EQUIPMENT	CAPACITY	NO. OF UNIT
	Cargo Truck	N/A	1
	Bagger Mixer	1 bagger	1
12	<i>No further instructions</i>		
15	<i>Each Bidder shall submit ONLY one (1) original copy of the first and second components of its bid.</i>		

15.1	<p>The bid security shall be in the form of a Bid Securing Declaration or any of the following forms and amounts:</p> <p>a. The amount of not less than two percent (2%) of ABC, if bid security is in cash, cashier’s/manager’s check, bank draft/guarantee or irrevocable letter of credit;</p> <p>b. The amount of not less than five percent (5%) of ABC if bid security is in Surety Bond.</p> <table><tr><th>Lot No.</th><th>2% of the ABC</th><th>5% of the ABC</th></tr><tr><td>1</td><td>Php 183,740.00</td><td>Php 459,350.00</td></tr><tr><td>2</td><td>Php 20,800.00</td><td>Php 50,000.00</td></tr><tr><td>3</td><td>Php 21,780.00</td><td>Php 54,450.00</td></tr><tr><td>4</td><td>Php 18,018.00</td><td>Php 45,045.00</td></tr><tr><td>TOTAL</td><td>Php 244,338.00</td><td>Php 610,845.00</td></tr></table>	Lot No.	2% of the ABC	5% of the ABC	1	Php 183,740.00	Php 459,350.00	2	Php 20,800.00	Php 50,000.00	3	Php 21,780.00	Php 54,450.00	4	Php 18,018.00	Php 45,045.00	TOTAL	Php 244,338.00	Php 610,845.00
Lot No.	2% of the ABC	5% of the ABC																	
1	Php 183,740.00	Php 459,350.00																	
2	Php 20,800.00	Php 50,000.00																	
3	Php 21,780.00	Php 54,450.00																	
4	Php 18,018.00	Php 45,045.00																	
TOTAL	Php 244,338.00	Php 610,845.00																	
19.2	Partial bids is not allowed.																		
20	Certificate of good standing and compliance with statutory obligations from SEC/DTI, PAGIBIG, PHILHEALTH, and SSS																		
21	<p>Additional contract documents relevant to the Project that may be required by existing laws and/or the Procuring Entity, such as <i>construction schedule and S-curve, manpower schedule, construction methods, equipment utilization schedule, construction safety and health program signed by the contractor, Certificate of Site Inspection</i> and other acceptable tools of project scheduling.</p> <p><i>Construction safety and health program approved by the DOLE shall be submitted by the declared lowest calculated and responsive bidder within the project implementation.</i></p>																		

Section IV. General Conditions of Contract

1. Scope of Contract

This Contract shall include all such items, although not specifically mentioned, that can be reasonably inferred as being required for its completion as if such items were expressly mentioned herein. All the provisions of RA No. 9184 and its 2016 revised IRR, including the Generic Procurement Manual, and associated issuances, constitute the primary source for the terms and conditions of the Contract, and thus, applicable in contract implementation. Herein clauses shall serve as the secondary source for the terms and conditions of the Contract.

This is without prejudice to Sections 74.1 and 74.2 of the 2016 revised IRR of RA No. 9184 allowing the GPPB to amend the IRR, which shall be applied to all procurement activities, the advertisement, posting, or invitation of which were issued after the effectivity of the said amendment.

2. Sectional Completion of Works

If sectional completion is specified in the **Special Conditions of Contract (SCC)**, references in the Conditions of Contract to the Works, the Completion Date, and the Intended Completion Date shall apply to any Section of the Works (other than references to the Completion Date and Intended Completion Date for the whole of the Works).

3. Possession of Site

3.1 The Procuring Entity shall give possession of all or parts of the Site to the Contractor based on the schedule of delivery indicated in the **SCC**, which corresponds to the execution of the Works. If the Contractor suffers delay or incurs cost from failure on the part of the Procuring Entity to give possession in accordance with the terms of this clause, the Procuring Entity's Representative shall give the Contractor a Contract Time Extension and certify such sum as fair to cover the cost incurred, which sum shall be paid by Procuring Entity.

3.2 If possession of a portion is not given by the above date, the Procuring Entity will be deemed to have delayed the start of the relevant activities. The resulting adjustments in contract time to address such delay may be addressed through contract extension provided under Annex "E" of the 2016 revised IRR of RA No. 9184.

4. The Contractor's Obligations

The Contractor shall employ the key personnel named in the Schedule of Key Personnel indicating their designation, in accordance with **ITB** Clause 10.3 and specified in the **BDS**, to carry out the supervision of the Works.

The Procuring Entity will approve any proposed replacement of key personnel only if their relevant qualifications and abilities are equal to or better than those of the personnel listed in the Schedule.

5. Performance Security

5.1. Within ten (10) calendar days from receipt of the Notice of Award from the Procuring Entity but in no case later than the signing of the contract by both parties, the successful Bidder shall furnish the performance security in any of the forms prescribed in Section 39 of the 2016 revised IRR.

5.2. The Contractor, by entering into the Contract with the Procuring Entity, acknowledges the right of the Procuring Entity to institute action pursuant to RA No. 3688 against any subcontractor be they an individual, firm, partnership, corporation, or association supplying the Contractor with labor, materials and/or equipment for the performance of this Contract.

6. Site Investigation Reports

The Contractor, in preparing the Bid, shall rely on any Site Investigation Reports referred to in the **SCC** supplemented by any information obtained by the Contractor.

7. Warranty

7.1. In case the Contractor fails to undertake the repair works under Section 62.2.2 of the 2016 revised IRR, the Procuring Entity shall forfeit its performance security, subject its property(ies) to attachment or garnishment proceedings, and perpetually disqualify it from participating in any public bidding. All payables of the GOP in his favor shall be offset to recover the costs.

7.2. The warranty against Structural Defects/Failures, except that occasioned-on force majeure, shall cover the period from the date of issuance of the Certificate of Final Acceptance by the Procuring Entity. Specific duration of the warranty is found in the **SCC**.

8. Liability of the Contractor

Subject to additional provisions, if any, set forth in the **SCC**, the Contractor's liability under this Contract shall be as provided by the laws of the Republic of the Philippines.

If the Contractor is a joint venture, all partners to the joint venture shall be jointly and severally liable to the Procuring Entity.

9. Termination for Other Causes

Contract termination shall be initiated in case it is determined *prima facie* by the Procuring Entity that the Contractor has engaged, before, or during the implementation of the contract, in unlawful deeds and behaviors relative to contract acquisition and implementation, such as, but not limited to corrupt, fraudulent, collusive, coercive, and obstructive practices as stated in **ITB** Clause 4.

10. Dayworks

Subject to the guidelines on Variation Order in Annex “E” of the 2016 revised IRR of RA No. 9184, and if applicable as indicated in the **SCC**, the Dayworks rates in the Contractor’s Bid shall be used for small additional amounts of work only when the Procuring Entity’s Representative has given written instructions in advance for additional work to be paid for in that way.

11. Program of Work

11.1. The Contractor shall submit to the Procuring Entity’s Representative for approval the said Program of Work showing the general methods, arrangements, order, and timing for all the activities in the Works. The submissions of the Program of Work are indicated in the **SCC**.

11.2. The Contractor shall submit to the Procuring Entity’s Representative for approval an updated Program of Work at intervals no longer than the period stated in the **SCC**. If the Contractor does not submit an updated Program of Work within this period, the Procuring Entity’s Representative may withhold the amount stated in the **SCC** from the next payment certificate and continue to withhold this amount until the next payment after the date on which the overdue Program of Work has been submitted.

12. Instructions, Inspections and Audits

The Contractor shall permit the GOP or the Procuring Entity to inspect the Contractor’s accounts and records relating to the performance of the Contractor and to have them audited by auditors of the GOP or the Procuring Entity, as may be required.

13. Advance Payment

The Procuring Entity shall, upon a written request of the Contractor which shall be submitted as a Contract document, make an advance payment to the Contractor in an amount not exceeding fifteen percent (15%) of the total contract price, to be made in

lump sum, or at the most two installments according to a schedule specified in the **SCC**, subject to the requirements in Annex “E” of the 2016 revised IRR of RA No. 9184.

14. Progress Payments

The Contractor may submit a request for payment for Work accomplished. Such requests for payment shall be verified and certified by the Procuring Entity’s Representative/Project Engineer. Except as otherwise stipulated in the **SCC**, materials and equipment delivered on the site but not completely put in place shall not be included for payment.

15. Operating and Maintenance Manuals

- 15.1. If required, the Contractor will provide “as built” Drawings and/or operating and maintenance manuals as specified in the **SCC**.
- 15.2. If the Contractor does not provide the Drawings and/or manuals by the dates stated above, or they do not receive the Procuring Entity’s Representative’s approval, the Procuring Entity’s Representative may withhold the amount stated in the **SCC** from payments due to the Contractor.

Section V. Special Conditions of Contract

GCC Clause	
2	No further instructions.
4.1	The Procuring Entity shall give possession of all parts of the Site to the Contractor <i>immediately after issuance of Notice to Proceed.</i>
6	The site investigation reports are: <i>[list here the required site investigation reports.]</i>
7.2	<p><i>[Select one, delete the other.]</i></p> <p><i>[In case of permanent structures, such as buildings of types 4 and 5 as classified under the National Building Code of the Philippines and other structures made of steel, iron, or concrete which comply with relevant structural codes (e.g., DPWH Standard Specifications), such as, but not limited to, steel/concrete bridges, flyovers, aircraft movement areas, ports, dams, tunnels, filtration and treatment plants, sewerage systems, power plants, transmission and communication towers, railway system, and other similar permanent structures:]</i> Fifteen (15) years.</p> <p><i>[In case of semi-permanent structures, such as buildings of types 1, 2, and 3 as classified under the National Building Code of the Philippines, concrete/asphalt roads, concrete river control, drainage, irrigation lined canals, river landing, deep wells, rock causeway, pedestrian overpass, and other similar semi-permanent structures:]</i> Five (5) years.</p> <p><i>[In case of other structures, such as bailey and wooden bridges, shallow wells, spring developments, and other similar structures:]</i> Two (2) years.</p>
10	a. No day works are applicable to the contract.
11.1	The Contractor shall submit the Program of Work to the Procuring Entity's Representative within <i>five (5) days</i> of delivery of the Notice of Award.
11.2	The amount to be withheld for late submission of an updated Program of Work is <i>[insert amount]</i> .
13	The amount of the advance payment <i>shall not exceed 15% of the total contract price and schedule of payment.</i>
14	Materials and equipment delivered on the site but not completely put in place shall be included for payment.
15.1	<p>The date by which operating and maintenance manuals are required is <i>[date]</i>.</p> <p>The date by which "as built" drawings are required is <i>[date]</i>.</p>
15.2	The amount to be withheld for failing to produce "as built" drawings and/or operating and maintenance manuals by the date required is <i>[amount in local currency]</i> .

Section VI. Specifications

LOT 1:

REPAIR OF AVRC II WING I, WING III AND WING IV ROOFING, CEILING & ROOM PARTITIONS

ITEM 1: GENERAL REQUIREMENTS

RELATED SECTIONS

All applicable provisions of the different divisions of the Specifications for each work trade shall apply for all items cited in this Summary.

INFERRED ITEMS AND WORK

Materials and workmanship deemed necessary to complete the works but NOT specifically mentioned in the Specifications, Working Drawings, or in the other Contract Documents, shall be supplied and installed by the Contractor without extra cost to the Owner. Such materials shall be of the highest quality available, and installed or applied in a workmanlike manner at prescribed or appropriate locations.

SPECIFICS

Materials specifically mentioned in this Summary shall be installed following efficient and sound engineering and construction practice, and especially as per manufacturer's application for installation specifications which shall govern all works alluded to in these Specifications.

ON-SITE ITEMS

Materials and finishes for on-site improvements and facilities as listed below are part of the scope of work and shall be supplied and installed by the Contractor without extra cost to the Owner.

A. Construction of:

1. Walks, ramps, steps, posts, perimeter fence and miscellaneous slabs;
2. Concrete catch basins, drainage pipes;
3. Temporary facilities and below grade structures such as septic vaults, cisterns, manholes, open canals, check drains and trenches;

- B. Exterior utility lines, raceway system, fixtures, breakers, switches, buzzers, controls including fittings and accessories as required by the specialty trades under plumbing, mechanical and electrical works.

OFF-SITE ITEMS

Off-site improvements shall generally be under the responsibility of the Owner and not included in the Contract, with the exception of the following which shall be part of the Contractor's Work:

Construction of drainage lines. This work shall neatly connect to the storm drainage system along the road. Permanent connections to the local utility lines for electrical, water, drainage, sewer and telephone lines including equipment, facilities, materials, fees, and/or work which utility companies or authorities may require of the applicant Owner, such as electrical transformers, etc.

WATER & ELECTRICITY CONNECTION

- A. Temporary Water: The Contractor shall supply in sufficient quantity all necessary potable and other water for construction purposes for all trades at a point within a reasonable distance of the building being constructed. The Contractor shall make arrangements and pay charges for water service installation, maintenance, and removal thereof, and pay the costs of water for all trades.
- B. Temporary Electricity: The Contractor shall make all necessary arrangements for a temporary electrical service, pay all expenses in connection with the installation, operation and removal thereof, and pay the costs of electricity consumed by all trades.

OWNER SUPPLIED ITEMS

Owner supplied finishing accessories, furnishing and fixtures such as wall clocks, picture frames, fixed furniture etc., shall be installed by the Contractor at no cost to the Owner.

QUALITY CONTROL

The Contractor shall be responsible for the quality control of all materials during the handling, blending, and mixing and placement operations. The Contractor shall furnish the Engineer a Quality Control Plan detailing his production control procedures and the type and frequency of sampling and testing to insure that the materials and work produces complies with the Specifications. The Engineer shall be provided free access to recent plant production records, and if requested, informational copies of mix design, materials certifications and sampling and testing reports.

The Contractor shall perform all sampling, testing and inspection necessary to assure quality control of the component materials.

ITEM (1.1): PROJECT BILLBOARD/SIGNBOARD

Project Billboards/COA signages shall be installed near the construction site or before the entrance gate and must be visible for the visitors.

Signage sizes: **Project Signage = 4ft. x 8ft.**
 COA Signage = 8ft. x 8ft.

ITEM (1.3): TEMPORARY FENCE

The whole area affected for the project shall be fenced temporarily with necessary gates as directed by the Engineer. The site must be closed enough and must not be visible for the clients living in the center.

ITEM 2: PLAIN AND REINFORCED CONCRETE WORK

ITEM (2.1): STRUCTURAL CONCRETE (CLASS A, 28 DAYS)

CEMENT – Use “CLASS A” PORTLAND CEMENT or approved equivalent.

CONCRETE AGGREGATES

1. Gravel: Well graded, clean, hard particles of gravel or crushed rock conforming to the “STANDARD SPECIFICATIONS FOR CONCRETE AGGREGATES” (ASTM Designated C-33 latest revision). Use 25 mm (1”) maximum for slabs and 19 mm (3/4”) for columns and beams and retaining walls.
2. Sand: ASTM C 35 – 67, clean, washed river sand, strong, free from organic and other deleterious materials. Sand from salt water or lahar is not allowed.
3. Maximum size of aggregates shall not be larger than 1/5 of the narrowest dimension between sides of the forms, not larger than 3/5 of the maximum clear spacing between reinforcing bars, and in no case larger than 33 mm (1-1/3”) in diameter.

WATER - Use only water that is clean and free from injurious amounts of oils, acids, alkali, organic materials or other deleterious substances. Potable/ fit for human consumption.

CONCRETE MIXES

Concrete compressive strength (f'c) requirements:

I. Specified Compressive Strength			
Class/Type	14 days		Item
	psi	mPa	
A	3000	28	For footings, columns, beams, lintels beam and stiffener columns, slab on grade and for all

			reinforced work not otherwise indicated or specified
B	1,500	10.34	For all concrete without reinforcement like lean concrete

Slump requirements:

Structural Element	Slump for vibrated concrete	
	Minimum	Maximum
Slab on grade, stair landing and tread	75 mm	125 mm
Other components	50 mm	100 mm

CONCRETE ADDITIVES

1. Use "CLASS A" in the amounts as recommended by the manufacturer, with the approval of the Architect.
2. Plasticizer – Use "CLASS A"
3. Air-entraining admixtures – Use "CLASS A" or approved equal to improve workability or durability of concrete mixes.
4. Accelerators – Use "CLASS A" or approved equal.
5. Water Reducing Retarders – Use "CLASS A" or approved equal.
6. Integral Waterproofing Compound – Use "CLASS A" or approved equal for roof slabs, balcony, concrete gutters, cisterns and media aguas. Refer to Manufacturer's manual/instruction for proper application.
7. Calcium chloride is not allowed. Secure approval of the Engineer prior to using of any other additive.

NOTE: PLACEMENT DRAWINGS: Shop drawings of each reinforcing steel detail and placement drawings shall be submitted for approval in accordance with the requirements of the General Conditions. Any material fabricated before final approval of the shop drawings will be done at Contractor's risk, but no material shall be placed until shop drawings have final approval. Shop drawings shall be in accordance with the "Manual of Standard Practice for Detailing Reinforced Concrete Structures" (ACI 315).

ITEM (2.2): REINFORCING STEEL (DEFORMED, GRADE 40)

Steel Bars – Use structural grade ASTM A615 Grade 40 for deformed bars 12mmØ and below. For 16mmØ and above, use structural grade ASTM 615 Grade 60. Deformed bars shall be new and free from rust, oil, grease, defects or kinks. Upgrade to next bigger size if specified standard sizes are unavailable.

Use **Ga.16 Galvanized Iron (G.I.)** tie wires at joints or laps of placed reinforcements.

Steel reinforcement shall be stored above the surface of the ground upon platforms, skids, or other supports and shall be protected as far as practicable from mechanical injury and surface deterioration caused by exposure to conditions producing rust. Distance from the forms shall be maintained by means

of stays, blocks, ties, hangers, or other approved supports, so that it does not vary from the position indicated on the Plans. Reinforcement in any member shall be placed and then inspected and approved by the Engineer before the placing of concrete begins. Concrete placed in violation of this provision may be rejected and removal may be required.

Splices: Splices shall be staggered as far as possible and with a minimum separation of not less than 40 bar diameters. Lapped splices will not be permitted at locations where the concrete section is insufficient to provide minimum clear distance of one and one-third the maximum size of coarse aggregate between the splice and the nearest adjacent bar.

ITEM (2.3): FORMWORKS, FALSEWORKS & SCAFFOLDINGS

1. Use Phenolic forms, plywood, metal or surfaced lumber forms, free from warp and gross deformities, sufficiently braced with solid lumber and applied with form release agent as its casting surface before each casting, where it will best give the most advantage in the specific concrete work involved.
2. For exposed reinforced concrete such as exposed beams and columns, use Phenolic forms or approved equivalent.
3. Provide 40mm-wide chamfers for all exposed corners of columns.
4. Do not use Coco lumber for formwork.
5. Use only good lumber or metal sections for forms.
6. Types of shoring and bracing systems include, but are not limited to, the following:
 - Timber Lagging
 - Steel Scaffolds
7. Provide sufficient shoring and soil retention protection options to prevent displacement and damage to existing adjacent structures, and cave-ins.

ITEM 3 : CIVIL/FINISHING WORKS

ITEM (3.1): REMOVAL OF STRUCTURES AND OBSTRUCTION

Existing structures shall be removed and cleared in preparation for new construction. The Contractor shall make arrangements with the Center Head/owner for the items needed and not needed for disposal. The Contractor shall be responsible for the disposal of the waste materials from the demolished structure.

ITEM (3.2): PLUMBING WORKS

All plumbing works herein shall be executed according to the requirements of philippine national plumbing code and the rules and regulations of the existing local codes and ordinances or laws governing the implementation of the plumbing works.

Refer to all electrical, structural and architectural plans and specifications and investigate all possible interference and conditions affecting the plumbing works.

It is not intended that the drawing shall show every pipe fitting, valve and appliances. Furnish and install, if necessary, all such item specially mentioned or not, or indicated on the drawing, to complete the system in accordance to the best practice of the plumbing trade and satisfaction of the engineer/owner.

Perform all labor in a first-class, neat, workmanlike manner by specialist skilled in their trades, and such specialist and their work shall be satisfactory to the engineer.

SEWER LINE WORKS

Trenches for underdrain outlets shall be excavated to the width and depth shown on the Plans or as otherwise directed. Pipes shall be laid in the trench with all ends firmly joined by the applicable methods and means. After inspection and approval of the pipe installation, the trench shall be backfilled in accordance with Item 103, Structure Excavation.

Trenches for blind drains shall be excavated to the width and depth shown on the Plans. The trench shall be filled with granular backfill material to the depth required by the Plans. Any remaining upper portion of trench shall be filled with either granular or impervious material in accordance with Item 103, Structure Excavation

After the pipe installation has been inspected and approved, granular backfill material shall be placed to a height of 300 mm above the top of pipe. Care shall be taken not to displace the pipe or the covering at open joints. The remainder of the granular backfill material shall then be placed and compacted in 150 mm maximum layers to the required height. Any remaining portion of trench above the granular backfill shall be filled with either granular or impervious material, as may be specified, and thoroughly compacted.

Clean-out Plugs: Cast brass ferrule with countersunk tap screw cover. For all drain and sewer lines requiring clean outs. N-240, ASA or equal.

Sanitary Pipes/Sewer Pipes/Fittings: shall be polyvinyl chloride (PVC) pipe series 1000, Use CLASS A with the same brand or approved equal. Fittings shall be solvent cement joint conforming to ASTM D2564.

Vent Pipes: shall be protected against siphonage and back pressure. Air circulation shall be assured throughout all parts of the excreta drainage system.

PLUMBING FIXTURES:

1. Install all plumbing fixtures free and open in a manner to access for Cleaning. Furnish with brackets, cleats, plates, and anchors required to Support the fixtures rigidly in place.

2. Keep away, at a sufficient distance but not less 1/2" (12.5 mm.) All service Pipes, valves, and fittings from surfaces and locations which may require Finish coats or covering.
3. Extend the piping to all fixtures, outlets, and equipment from required Gate valves installed in each branch near risers.

SOIL, WASTE, DRAIN, AND VENT PIPINGS:

1. Install all piping works in conformity with all provisions of the latest Edition of the Philippine national plumbing code and applicable requirements Of the existing local codes.
2. Excavate to require depths and grades. All excavations required for the Installations of plumbing and drainage system when rock is encountered, Extend the excavation to a depth 150 mm. Below the pipe bottom of the pipe and rock surface with sand and approved material.
3. Lay water supply pipes and sewers in separate trenches.

TRAPS

1. Except for the presence of grease trap interceptor and other devices Where the trap is an integral part of the design. Equipped with a trap every Fixture and equipment requiring connections to the drainage system.
2. Set each trap as close as possible to the fixture served and render level with respect to their water seal.

PLUMBING PIPES AND FITTINGS

1. All materials to be used must be of high quality.
2. Air chamber to be provided for all water line outlets. All necessary fitting Shall be provided.
3. Teflon tape for all waterline connections applied to male threads only.
4. Make all joints air and water tight. For jointing pipes, use the following:
 - a. PVC& CPVC pipes: use appropriate couplers and glue at joints.
 - b. PPR pipes; when connecting with other pipe fittings, do not use, if possible, Male pipe fittings with conic thread and hemp as a sealing material to avoid Buckling stresses which act on female pipe fitting.

GUARANTEE AND WARRANTY

1. The contractor shall guarantee all materials supplied and the work to be Free from factory defects and workmanship for a period of one (1) year.
2. Any material found to be defective during the time of construction shall be replaced by the contractor free of charge.

CLEAN OUTS

For clean outs stemming from pvc, provide with long sweep quarter bends or one or two eight bends, extended to an easily accessible place, and Generally where indicated in the drawings

OTHERS

1. Provide cleanouts every 15meters for horizontal piping of more than 15 meters
Pipes shall be installed as indicated, any relocation required for proper
Execution of other trades shall be prior approval of the engineer.
2. Proposed sanitary utilities shall conform to the actual location, depth, and
Invert elevations.
3. All fixtures shall be vented, unless otherwise indicated.

Plumbing fixtures shall be of dense, durable, non-absorbent materials and must have smooth, impervious surfaces, free from unnecessary concealed fouling surfaces. All porcelain enamel surfaces on plumbing fixtures shall be acid resistant. No water supply system or portion thereof shall be covered or concealed until it has been first inspected, tested and approved. The piping system shall be air tested or water tested. The contractor shall notify the Engineer in-charge that said work is ready for inspection.

1. **Cold Water Lines:** Shall be Polypropylene Plastherm (PN-20) PPR Pipes and Fittings, Use CLASS A or approved equal conforming to ISO 4065 standard dimensions, using manufacturer specified method of installation and connection.
2. **Valves:** ASTM B-61 & 62, ASTM A 197, PRICE PFISTER (U.S.), KITZ or CRANE or approved equal. For gate valves and check valves, cast brass, sizes as required in the drawings. 150 psig working connection
3. **Hose Bibb:** Stainless steel faucet for all toilet cubicles and for garden hoses size 12mm male inlet and 12mm hose thread, and Use "CLASS A "lever type" with bronze body as indicated in the plans.
4. **Floor Drains:** METMA, M-200-D, MAB or approved equal, 150mm x 150mm (6"x6"). For toilets, and where so indicated in drawings. METMA M-249-12 MAB, 100mm x 100mm (4" x 4") and 200mm x 200mm (8"x8"). Floor drains shall connect into a trap so constructed that it can be readily cleaned and of a size to serve efficiently the purpose for which it is intended.
5. **Water Closet-** shall be vitreous china, siphon vortex design, close coupled make, flush tank, elongated front and free from defects.
6. **Urinal-** shall be porcelain make, installed at not less than 600mm from the finish floor line to the top of the overflow rim. An approved type vacuum breaker shall protect every water supply to a urinal or other approved backflow prevention device.
7. **Lavatory-** shall be wall hung, ceramic, oval type and free from defects. It shall be rigidly supported by metal supporting members or chairs so that no bending or pullout strain is transmitted to the wall.
8. **Kitchen Sink and Laundry tray-** shall be stainless steel gauge 304 make, hairline finish.
9. **Water Meter-** shall be 32mm diameter, Heavy Duty, brand new and free from defects.

ITEM (3.3): CEILING AND FACIA BOARD (FIBER CEMENT)

1. **Fiber Cement Board:** Use “CLASS A”, Install as per manufacturer’s instructions. 6mm thick for all suspended ceilings and 19mm for facia board. See drawing details for Suspended Ceiling and facia board.
2. **Suspended Ceiling System:** Use 25mm x 50mm x 0.6mm thk metal furring, 12mmØ suspension rod, suspension clips, eyelets, attached to ceiling framing.
3. **Ceiling Framing:** Use 2” x 4” x 1.2mm thk. C-Purlins painted with anti-rust as carrying channel. C-Purlins must be welded properly to the wall angle (2” x 2” x 6mm thk. Angle bar).
4. **Wall Angle:** Use 2” x 2” x 6mm thk. Angle Bar bolted to the wall at every 0.6m.
5. Provide edgings, trims and moldings and others as indicated in the drawings.
6. **Hardware and Fasteners:** Use metal nails, screws, bolts, plates, straps, miscellaneous fasteners or anchorage concealed or countersunk whenever called for, with size, shape and type to ensure a rigid connection for laminated items and at other framing joints.

ITEM (3.6): FRAMES, JAMBS

Jambs: Use 150mm x 50mm kiln-dried, treated S4S, sound, hard and free from lumber. Use one color or shade for assembly framing which are exposed. Provide with wood trim for all wooden doors.

Use “Class A”: Sound and thoroughly seasoned, warp free, treated with pressure impregnated “CLASS A” preservative or approved equal, smooth and level on one side or wherever in contact with paneling for nailers, and all wooden members hidden from viewer.

Hardware and Fasteners: Use metal nails, screws, bolts, plates, straps, miscellaneous fasteners or anchorage concealed or countersunk whenever called for, with size, shape and type to ensure a rigid connection for laminated items and at other framing joints.

ITEM (3.7 & 3.8): DOORS

DOOR, Solid Wood, Use “Class A”: Sound and thoroughly seasoned, warp free, treated with pressure impregnated “CLASS A” preservative or approved equal, smooth and level on one side or wherever in contact with paneling for nailers, and all wooden members hidden from viewer.

Flush Doors, Refer to Door Schedule.

Viewing Panel: Should be 6mm thick tempered glass. Use Class A and install as per manufacturers instruction.

Use “CLASS A” for all door hardware, and closet hardware except where indicated otherwise. Provide Master Key for the entire house, for all cylindrical locksets and deadbolt locking devices.

All door lock must be lever type, class A.

ITEM (3.9): TEMPERED GLASS

DOOR: Use 12mm thk. Tempered Bronze Glass Door, swing type with, frameless with 38mm dia. Stainless steel 304 door handle.

VIEWING GLASS: Use 12mm thk. Tempered Bronze Glass Door, fixed type, with one way glass tint.

ITEM (3.10, 3.11 & 3.12): METAL ROOFING SHEETS, FLASHINGS, GUTTER AND ACCESSORIES

Pre-formed Metal Roofing: Use “CLASS A” Oven-baked, Pre-painted G.I. Long Span Hi-Rib, 0.6mm thick with complete accessories. Submit sample for Engineer’s approval.

Use “CLASS A”, Oven Baked, Ridge rolls and vent, flashings, cappings, gutters, trims, and mouldings: 0.6 mm thick (Preformed).

Strainer: Use “CLASS A” Brass Dome Strainers or Stainless Steel leaf strainer. Submit sample for Engineer’s approval.

Fasteners and Fixation: Use appropriate connectors as recommended by the manufacturer and approved by the Architect. Paint same color as roof, all exposed fixation and fastening devices. Apply fasteners in a neat, consistent, even and standard manner. Apply strip of butyl rubber-based caulking compound along all end lap joints and passing over pre-drilled fixation holes. For fixation of metal sheet to “C” purlins and when lapped over another metal sheet. For fixation of flashing. Use Tek screws for roof eaves area, where roof frames are exposed.

Sealants: “CLASS A” Sealants shall be used in areas necessary to render structure watertight, sufficient even during strong winds:

ITEM (3.13): WATERPROOFING

Apply with surface preparation, methods application and density as per manufacturer’s specifications. Apply to all water holding concentrate vessels; like toilet slabs and concrete gutters.

ITEM (3.14): TILES

Use glazed tile for walls and unglazed tile for floors. Tiles must be soak to water for atleast 3 hours before installation. Refer to schedule of tiles.

1. **Mortar:** Use Portland Cement or any approved equivalent.
2. **Sand:** ASTM C 35 – 67, clean, washed river sand, strong, free from organic and other deleterious materials. Sand from salt water or lahar is not allowed.
3. **Water:** Fit for drinking, free from injurious amount of oil, acids, alkali, organic materials and other deleterious substances.
4. **Adhesive Mortar:** Use “CLASS A” for laying vitrified ceramic tiled.
5. **Grout:** Use “Class A” pre-mixed dry wall filler for floor and wall tile either glazed or semi-glazed tiles. Masonry concrete grout compressive strength (fc') = 13.8 Mpa (2000 psi).
6. **Plaster Bond:** Use “Class A” or approved equal. Apply on all wall areas, as required, prior to plastering. Suppliers shall furnish product description prior to purchase and delivery.

ITEM (3.15): CEMENT PLASTER FINISH

PLAIN CEMENT PLASTER FINISH: Consisting of the scratch and finish coats. Use “CLASS A” for the base/scratch coat, and “CLASS A” for the finish coat. Refer to Manufacturer’s technical data for proper application. Shall apply for all beams and columns if fine finish cannot be achieved from off form finish and for all interior and exterior walls, and where plastering is essential to complete the work. Use Portland Cement or any approved equivalent.

Sand: ASTM C 35 – 67, clean, washed river sand, strong, free from organic and other deleterious materials. Sand from salt water or lahar is not allowed.

Water: Fit for drinking, free from injurious amount of oil, acids, alkali, organic materials and other deleterious substances

ITEM (3.16): PAINTINGS (CEMENT, WOOD AND METAL)

All paint and paint materials called for under this section shall be as manufactured by known manufacturer or owner approved equivalent and must be LEAD-FREE Paint. Use CLASS A only (one brand all throughout). All exposed finish hardware, lighting fixtures and accessories, plumbing fixtures and accessories, glasses and the like shall be adequately protected that these areas are not stained with paint and other painting materials prior to painting works. All other surfaces which would be endangered by stains or paint marks should be taped and covered with craft paper or equal.

Exterior: Use “CLASS A” paint PLAIN FINISH for all exterior finishes and as shown in the drawings and for all exposed and/or visible concrete and masonry surfaces, as well as for exterior HARDIFLEX surfaces unless otherwise specified.

Surface Preparation: Concrete and masonry surfaces must be fully cured for at least 14 days.

1st coat: Use Class A Concrete Primer And Sealer (as manufacturer instruction)

2nd coat: Use Class A Putty

3rd and 4th coats: Use Class A Concrete Primer and Sealer

Interior: USE “CLASS A” SKIM COAT PLAIN FINISH for minor interior walls indicated in the drawings and for all interior concrete and masonry surfaces unless otherwise specified.

Surface Preparation: Concrete and masonry surfaces must be fully cured for at least 14 days.

Metal Surfaces: Use “CLASS A” Liquid Tile. For ferrous surfaces such as steel and roof framing and other exposed steel surfaces unless otherwise specified.

Surface Preparation: Must be free from rust.

1st coat: Use CLASS A Primer Red Oxide

2nd and 3rd coats: Use CLASS A Aqua Gloss-It

Use only approved brand of epoxy zinc chromate paint and linseed oil for all base coat painting for structural steel. For finish painting, use enamel paint or approved equal.

Color codes for DSWD Facilities:

Interior Walls	:	Seed Pearl color
Exterior Walls	:	Dapper Tan Color
Baseboards	:	Shrimp Pink/Chocolate brown
Wooden Doors & Jambs	:	Wood Stain (One-way application)
Ceiling	:	Plain White

ITEM (3.17): CONCRETE HOLLOW BLOCKS (CHB)

Interior Walls - Use 4” thk Load Bearing Concrete Hollow Block Units of standard manufacture, machine vibrated with even texture and well defined edges, conforming to PNS16 Type 1, Class A, with a minimum compressive strength of 4.82 Mpa (700 psi)

Steel Bars – Use structural grade ASTM A615 Grade 40 deformed bars 12mmØ and below. Deformed bars shall be new and free from rust, oil, grease, defects or kinks. Upgrade to next bigger size if specified standard sizes are unavailable. Use Ga.16 Galvanized Iron (G.I.) tie wires at joints or laps of placed reinforcements.

Provide reinforced concrete lintel beams and jambs on all masonry openings.

1. **Cement** – Use “CLASS A” PORTLAND CEMENT or approved equivalent.
2. **Aggregates**
 - a. Aggregates shall be well-graded, clean, hard particles or gravel or crushed rock conforming to the STANDARD SPECIFICATION FOR CONCRETE AGGREGATES (ASTM Designation C-33: latest revision).
 - b. Sand – ASTM C 35 – 67, clean, washed river sand, strong, free from organic and other deleterious materials. Sand from salt water is not allowed.
3. **Water** – Shall be clean and free from injurious amounts of oils, acids, alkali, organic materials or other deleterious substances.

ITEM (3.18): STRUCTURAL STEEL (TRUSSES, PURLINS), METAL STRUCTURES AND ACCESSORIES

Conform all materials and workmanship to the requirements of the American Institute of Steel Construction "Specifications for Design, Fabrication and Erection of Structural Steel for Buildings" as amended to date or as may be specifically modified by the drawings or by these Specifications.

Welding shall be performed by the metal-arc process, using the electrodes specified with either direct or alternating current. Conform all materials and workmanship to the requirements of the American Institute of Steel Construction "Specifications for Design, Fabrication and Erection of Structural Steel for Buildings" as amended to date or as may be specifically modified by the drawings or by these Specifications. Welding of Structural Steel shall be done only when shown on the Plans or authorized in writing by the Engineer.

Surfaces to be welded shall be smooth, uniform and free from fins, tears, and other defects which would adversely affect the quality of the weld. Edges of material shall be trimmed by machining, chipping, grinding, or machine gas-cutting to produce a satisfactory welding edge wherever such edge is thicker than: 13 mm for sheared edge of material; 16 mm for toes of angles or rolled shapes (other than wide flange sections); 25 mm for universal mill plate or edges of flange sections.

No operation or actual welding or gas-cutting shall be performed on a member while it is carrying live load stress or while subject to shock and vibration and from moving loads. Welding and gas-cutting shall cease in advance of the application of such loads.

Plates, Sheets, Flange and Connectors: Conform to ASTM Designation A36 with specified yield point of 248 Mpa (36,000 psi). From mild steel sheets or plates with standard thickness, size, shape and design as indicated in the plans. For miscellaneous stiffener, bearing anchorage and connector plates or straps. Upgrade to next higher / bigger size and thickness if specified sizes & thicknesses are unavailable.

Standard solid section: Conform to ASTM 611 with specified yield point of 228 Mpa (33,000 psi). Mild steel angles, flat bars, square bars, channels, U and other sections. For purlins, building eaves framing, grill works, miscellaneous fabricated mounting brackets, straps, dowels, frames and connectors. Upgrade to next higher / bigger size and thickness if specified sizes & thickness are unavailable.

Bolt Accessories: Bolts, nuts circular washers shall conform to High-Strength Bolts for Structural Steel Joints, including Suitable Nuts and Plain Hardened Washer, AASHTO M 164 (ASTM A 325).

Fastenings - Commercial types, except where special types are shown or required. Fastenings for all exterior work shall be non-ferrous, unless otherwise shown. Fastening for stainless steel and aluminum and other interior work, where exposed shall match the fastened metal.

Angle bars, Purlins and Rectangular Tube: Conform to ASTM 611 with specified yield point of 228 Mpa (33,000 psi). Mild steel angles, flat bars, square bars, channels, U and other sections. For purlins, building eaves framing, grill works, miscellaneous fabricated mounting brackets, straps, dowels, frames and connectors. Refer to trusses and purlins schedule for thickness, size, shape and design. Refer to Sun-baffle schedule for rectangular tubing. Upgrade to next higher / bigger size and thickness if specified sizes & thicknesses are unavailable.

Welding Electrodes: Conform welding electrodes to ASTM Specification A233 and AWS Specification A5.1 and A5.5 E60 series for manual shielded metal arc welding and E-70 series for structural welding.

Painting: Use only approved brand of epoxy zinc chromate paint and linseed oil for all base coat painting for structural steel. For finish painting, use enamel paint or approved equal.

Metal Hangers - Use "CLASS A" or approved equal.

Brass Iron – 2" Ø pipe for **ramps and stairs**.

Stainless Steel - 2" Ø pipe for **CR grab bars**

Stair Nosing – use 2.5" x 2.5" stair nosing and must be welded to the stair dowels before concreting

No operation or actual welding or gas-cutting shall be performed on a member while it is carrying live load stress or while subject to shock and vibration and from moving loads. Welding and gas-cutting shall cease in advance of the application of such loads.

ITEM 5: ELECTRICAL

WIRES AND CABLES: Use “CLASS A” or approved equal.

1. All wires shall be copper, soft-drawn and annealed, shall be of 99% conductivity, shall be smooth and true and of a cylindrical form and shall be within 1% of the actual size called for.
2. All wires and cables shall comply with the requirements of the Underwriter’s Laboratories, the A.S.T.M. and the I.P.C.E.A. EIA/TIA as they apply in the particulars.
3. Wire and cables for lighting power and auxiliary systems shall be plastic insulated for 600 volts working pressure, type THHN unless otherwise noted on plans.
4. For lighting and power system, no wire smaller than 2.0mm dia. shall be used.
5. All wires and cables shall be color-coded and as manufactured by cable manufacturers. Colors coding of wires are as follows:

Line A – Blue	Ground – Green
Line B – Red	
Line C – Yellow	Control wires – other color

6. No conductor shall be less than 3.5 mm² in size unless otherwise specified. 600-volts wires and cables should meet the requirements of NFPA 70 and UL for the type of insulation, jacket and conductor specified or indicated in all power and lighting wires shall be 600-volt, type THW or THHN.

CONDUITS: Use “CLASS A” Schedule 40 PVC for conduits embedded in concrete and inside ceiling. Use “CLASS A” or Rigid Steel Conduit (RSC) for main service entrance exposed to weather.

1. Metallic conduits for interior and exterior systems shall be a standard weight, mild steel, hot-dip galvanized with an interior coating. Non metallic conduits shall be PVC electrical grade.
2. No conduits shall be used in any system smaller than 15mm dia. electrical trade size, nor shall have more than four 90-degree bends in any one run and when necessary, pull boxes shall be provided as directed. Location and sizes of pull boxes shall be cleared to the engineer prior to fabrication and installation.
3. No wires shall be pulled into any conduit unless the conduit system is complete in all details. In the case of concealed work, until all rough plastering or masonry has been completed and in the case of exposed work, until the conduit has been completed in every detail.

4. The ends of all conduits shall be tightly plugged to exclude plaster, dust and moisture while the building is in the process of construction.
5. All conduit and fittings on exposed work shall be secured by means of Kindoff channels and clamps. Conduit lay outing, in all cases shall run perfectly straight and true, satisfactory to the architect and to the engineer.

OUTLET, BOXES, AND FITTINGS

1. **Convenience Outlets:** Use “CLASS A”, white color, 220V, 16 amperes or as required. For general building interior use.
2. **Weatherproofed Outlets:** Use “CLASS A”, double device plate with cover receptacle, heavy duty as indicated on drawings.
3. **Boxes:** Use “CLASS A” metal utility boxes, sizes and shapes as required.
4. All outlets of whatever kind, for all systems, these shall be provided with suitable fittings, which shall be either a box or other devices especially designed to receive the type of fittings to be mounted thereon.
5. The contractor shall consult with the architect and the engineers as to the nature of the various fittings to be used before installing the outlet fittings and shall conform strictly in the use of such fittings, to the nature of the appliance to be mounted on them, so that the work, when finished will be a completed design.
6. In the case of fixtures, the outlet fittings shall be provided with suitable fixture supports of a size and kind required by the fixture to be hung. Fixture studs in general shall be 9.375mm
7. At all outlets on concealed conduit work, provide galvanized deep-type pressed-steel, outlet boxes of standard make. These boxes shall be especially designed for apparatus required and in all cases where such boxes are not available on the market; special boxes shall be made by the contractor at his own expense. Outlet boxes shall be deep type gage # 16.

JUNCTION, AND PULL BOXES

Junction and pull boxes per code gage steel, shall only be subject to the permission of the engineer and be provided as indicated or as required for facilitating the pulling of wires and cables. Pull boxes in finished places shall be located and installed only with the permission of and to the satisfaction of the architect and engineer.

SWITCHES, AND OUTLETS

1. Switches Use “CLASS A”, white color, flush type rate 220 volts to 16 amperes. Suited to location and intended purpose. Certain combinations shall be furnished with pilot lights as required where indicated on the drawings.
2. Switches shall be made of quick-connect terminal operated. The type of switch shall be tumbler operation. Samples shall be submitted prior to the purchase of wall switches and wall plates.

3. Receptacle, outlets shall be for flush mounting, duplex rated at 16 ampere, 250 volts, grounding type 3-wire, color: white. Samples of outlets and plates shall be submitted prior to purchase of devices.
4. Circuit Breakers: Use "CLASS A" or equivalent, bolt-on type, pre-painted, surface mounted, with latch lock.
5. Magnetic Starter: with NEMA-3 casing approved equal, surface mounted with latch lock.
6. Metal Enclosures and Cabinets Use "CLASS A" or approved equal.

PANELS AND CABINETS

Panel Boards: Use the existing Panel Boards

LOCATION OF WIRING AND OUTLETS

The contractor shall coordinate his work with all trades involved so that exact locations may be obtained for all outlets, apparatus, appliances and equipment. The circuit numbers indicated as numbers 1, 2, 3, may not correspond to actual panel circuit connection numbers but must be balanced for better load distribution.

The location of outlets shown on diagrammatic wiring plans shall be considered as approximate and it shall be incumbent upon the Contractor, before installation of outlet boxes, to study all pertinent drawings and obtain precise information from the architectural schedules, scale drawings, large scale and full size details of finished rooms and the approved shop drawings of other trades or from the architect. In centering the outlets, due allowance shall be made for window and door trims, variations in thickness of pouring, plastering, etc., as erected, regardless of conditions which may be otherwise shown on small scale drawings. Outlets incorrectly located shall be properly relocated at the contractor's expense. Local switches shown near the doors shall be verified with the architect's drawings before installation.

SERVICES

Power supply shall be three - phase

POWER AND LIGHTING DISTRIBUTION

Furnish and install the lighting panels as indicated on plans and panel board's schedule. From the main breaker, install feeders to the various outlying panels, motors or equipment as shown on plans. Feeders shall be inside the ceiling with hangers, channel and clamps

LIGHTING SYSTEMS

The lighting shall be complete in every respect, all as indicated on the plans or specified. All wiring's shall be installed in electrical non-metallic tubing using

compression type fittings and connectors or as indicated in the plan and in general shall be concealed in the structure. Mounting heights of devices shall be as detailed on the plans or as follows:

Local switches	– 1370mm from center of device to finished floor Line
Receptacles	– 300mm above floor or 150mm above counter or As shown on architectural details.

ITEM 6. MECHANICAL

ITEM 1200(13) AIRCONDITIONING

This section includes installation of air-conditioning units with complete accessories. All materials whether specifically mentioned or not in the technical plan, but necessary to complete this item of work shall be furnished and installed in the best workmanship practice. All materials used shall be of high standard quality.

Air-conditioning Units:

3HP Wall Mounted, Split type

All items shall be installed with vibrator insulator, angle brace, with complete accessories.

CLEANING-UP

The contractor shall at all times keep the construction area, including storage areas used by him, free from accumulations of waste materials or rubbish and prior to completion of work. Remove any rubbish from and about the premises and all tools, scaffolding, equipment and materials not the property of the owner.

Upon the completion of the construction, the contractor shall leave the work and premises in a condition satisfactory to the owner and the engineer.

PROJECT CLOSE-OUT

Upon completion of the project, the following procedure shall be implemented:

1. Walk-thru inspection by the owner, engineer and contractor. Any discrepancy noted shall be fixed before the project is closed.
2. Compile a complete equipment maintenance manual for all equipment. Submit copy of “As-built” drawings to the owner and engineer.
3. Construction Logbook with complete data (template will be provided by DSWD) must be submitted to the owner/engineer.

*****END OF SPECIFICATIONS*****

Section VI. Specifications

LOT 2:

REPAIR OF AVRC II COVERED COURT ROOFING, CEILING AND STAGE WALL

ITEM 1: GENERAL REQUIREMENTS

RELATED SECTIONS

All applicable provisions of the different divisions of the Specifications for each work trade shall apply for all items cited in this Summary.

INFERRED ITEMS AND WORK

Materials and workmanship deemed necessary to complete the works but NOT specifically mentioned in the Specifications, Working Drawings, or in the other Contract Documents, shall be supplied and installed by the Contractor without extra cost to the Owner. Such materials shall be of the highest quality available, and installed or applied in a workmanlike manner at prescribed or appropriate locations.

SPECIFICS

Materials specifically mentioned in this Summary shall be installed following efficient and sound engineering and construction practice, and especially as per manufacturer's application for installation specifications which shall govern all works alluded to in these Specifications.

ON-SITE ITEMS

Materials and finishes for on-site improvements and facilities as listed below are part of the scope of work and shall be supplied and installed by the Contractor without extra cost to the Owner.

C. Construction of:

4. Walks, ramps, steps, posts, perimeter fence and miscellaneous slabs;
5. Concrete catch basins, drainage pipes;
6. Temporary facilities and below grade structures such as septic vaults, cisterns, manholes, open canals, check drains and trenches;

- D. Exterior utility lines, raceway system, fixtures, breakers, switches, buzzers, controls including fittings and accessories as required by the specialty trades under plumbing, mechanical and electrical works.

OFF-SITE ITEMS

Off-site improvements shall generally be under the responsibility of the Owner and not included in the Contract, with the exception of the following which shall be part of the Contractor's Work:

Construction of drainage lines. This work shall neatly connect to the storm drainage system along the road. Permanent connections to the local utility lines for electrical, water, drainage, sewer and telephone lines including equipment, facilities, materials, fees, and/or work which utility companies or authorities may require of the applicant Owner, such as electrical transformers, etc.

WATER & ELECTRICITY CONNECTION

- C. Temporary Water: The Contractor shall supply in sufficient quantity all necessary potable and other water for construction purposes for all trades at a point within a reasonable distance of the building being constructed. The Contractor shall make arrangements and pay charges for water service installation, maintenance, and removal thereof, and pay the costs of water for all trades.
- D. Temporary Electricity: The Contractor shall make all necessary arrangements for a temporary electrical service, pay all expenses in connection with the installation, operation and removal thereof, and pay the costs of electricity consumed by all trades.

OWNER SUPPLIED ITEMS

Owner supplied finishing accessories, furnishing and fixtures such as wall clocks, picture frames, fixed furniture etc., shall be installed by the Contractor at no cost to the Owner.

QUALITY CONTROL

The Contractor shall be responsible for the quality control of all materials during the handling, blending, and mixing and placement operations. The Contractor shall furnish the Engineer a Quality Control Plan detailing his production control procedures and the type and frequency of sampling and testing to insure that the materials and work produces complies with the Specifications. The Engineer shall be provided free access to recent plant production records, and if requested, informational copies of mix design, materials certifications and sampling and testing reports.

The Contractor shall perform all sampling, testing and inspection necessary to assure quality control of the component materials.

ITEM (1.1): PROJECT BILLBOARD/SIGNBOARD

Project Billboards/COA signages shall be installed near the construction site or before the entrance gate and must be visible for the visitors.

Signage sizes: **Project Signage = 4ft. x 8ft.**
 COA Signage = 8ft. x 8ft.

ITEM (1.3): TEMPORARY FENCE

The whole area affected for the project shall be fenced temporarily with necessary gates as directed by the Engineer. The site must be closed enough and must not be visible for the clients living in the center.

ITEM II : CIVIL/FINISHING/ STRUCTURAL WORKS

ITEM (2.1): REMOVAL OF STRUCTURES AND OBSTRUCTION

Existing structures shall be removed and cleared in preparation for new construction. The Contractor shall make arrangements with the Center Head/owner for the items needed and not needed for disposal. The Contractor shall be responsible for the disposal of the waste materials from the demolished structure.

ITEM (2.2): SCAFFOLDINGS

The Contractor shall be responsible for the quality control & stability of all scaffoldings to be used in the project.

ITEM (2.3 & 2.4): CEILING AND WALL

7. **Fiber Cement Board:** Use “CLASS A”, Install as per manufacturer’s instructions. 6mm thick for all suspended ceilings, dry wall partitions and 19mm for facia board. See drawing details for Suspended Ceiling and facia board.
8. **Suspended Ceiling System:** Use 25mm x 50mm x 0.6mm thk metal furring, 12mmØ suspension rod, suspension clips, eyelets, attached to ceiling framing.
9. **Ceiling Framing:** Use 2” x 4” x 1.2mm thk. C-Purlins painted with anti-rust as carrying channel. C-Purlins must be welded properly to the wall angle (2” x 2” x 6mm thk. Angle bar).
10. **Wall Angle:** Use 2” x 2” x 6mm thk. Angle Bar bolted to the wall at every 0.6m.
11. Provide edgings, trims and moldings and others as indicated in the drawings.
12. **Wall Framing:** Use 2’ x 2” x 2mm thk. Square tube spaced at 0.4m O.C., both ways as main frame.
13. **Hardware and Fasteners:** Use metal nails, screws, bolts, plates, straps, miscellaneous fasteners or anchorage concealed or countersunk whenever

called for, with size, shape and type to ensure a rigid connection for laminated items and at other framing joints.

ITEM (3.10, 3.11 & 3.12): METAL ROOFING SHEETS, FLASHINGS, GUTTER AND ACCESSORIES

Pre-formed Metal Roofing: Use “CLASS A” Oven-baked, Pre-painted G.I. Long Span Hi-Rib, 0.6mm thick with complete accessories. Submit sample for Engineer’s approval.

Use “CLASS A”, Oven Baked, Ridge rolls and vent, flashings, cappings, gutters, trims, and mouldings: 0.6 mm thick (Preformed).

Strainer: Use “CLASS A” Brass Dome Strainers or Stainless Steel leaf strainer. Submit sample for Engineer’s approval.

Fasteners and Fixation: Use appropriate connectors as recommended by the manufacturer and approved by the Architect. Paint same color as roof, all exposed fixation and fastening devices. Apply fasteners in a neat, consistent, even and standard manner. Apply strip of butyl rubber-based caulking compound along all end lap joints and passing over pre-drilled fixation holes. For fixation of metal sheet to “C” purlins and when lapped over another metal sheet. For fixation of flashing. Use Tek screws for roof eaves area, where roof frames are exposed.

Sealants: “CLASS A” Sealants shall be used in areas necessary to render structure watertight, sufficient even during strong winds:

ITEM (3.13): WATERPROOFING

Apply with surface preparation, methods application and density as per manufacturer’s specifications. Apply to all water holding concentrate vessels; like toilet slabs and concrete gutters.

ITEM (3.16): PAINTINGS (CEMENT, WOOD AND METAL)

All paint and paint materials called for under this section shall be as manufactured by known manufacturer or owner approved equivalent and must be LEAD-FREE Paint. Use CLASS A only (one brand all throughout). All exposed finish hardware, lighting fixtures and accessories, plumbing fixtures and accessories, glasses and the like shall be adequately protected that these areas are not stained with paint and other painting materials prior to painting works. All other surfaces which would be endangered by stains or paint marks should be taped and covered with craft paper or equal.

Exterior: Use “CLASS A” paint PLAIN FINISH for all exterior finishes and as shown in the drawings and for all exposed and/or visible concrete and masonry surfaces, as well as for exterior HARDIFLEX surfaces unless otherwise specified.

Surface Preparation: Concrete and masonry surfaces must be fully cured for at least 14 days.

1st coat: Use Class A Concrete Primer And Sealer (as manufacturer instruction)

2nd coat: Use Class A Putty

3rd and 4th coats: Use Class A Concrete Primer and Sealer

Interior: USE “CLASS A” SKIM COAT PLAIN FINISH for minor interior walls indicated in the drawings and for all interior concrete and masonry surfaces unless otherwise specified.

Surface Preparation: Concrete and masonry surfaces must be fully cured for at least 14 days.

Metal Surfaces: Use “CLASS A” Liquid Tile. For ferrous surfaces such as steel and roof framing and other exposed steel surfaces unless otherwise specified.

Surface Preparation: Must be free from rust.

1st coat: Use CLASS A Primer Red Oxide

2nd and 3rd coats: Use CLASS A Aqua Gloss-It

Use only approved brand of epoxy zinc chromate paint and linseed oil for all base coat painting for structural steel. For finish painting, use enamel paint or approved equal.

Color codes for DSWD Facilities:

Interior Walls	:	Seed Pearl color
Exterior Walls	:	Dapper Tan Color
Baseboards	:	Shrimp Pink/Chocolate brown
Wooden Doors & Jambs	:	Wood Stain (One-way application)
Ceiling	:	Plain White

ITEM (3.17): CONCRETE HOLLOW BLOCKS (CHB)

Interior Walls - Use 4” thk Load Bearing Concrete Hollow Block Units of standard manufacture, machine vibrated with even texture and well defined edges, conforming to PNS16 Type 1, Class A, with a minimum compressive strength of 4.82 Mpa (700 psi)

Steel Bars – Use structural grade ASTM A615 Grade 40 deformed bars 12mmØ and below. Deformed bars shall be new and free from rust, oil, grease, defects or kinks. Upgrade to next bigger size if specified standard sizes are unavailable. Use Ga.16 Galvanized Iron (G.I.) tie wires at joints or laps of placed reinforcements.

Provide reinforced concrete lintel beams and jambs on all masonry openings.

4. Cement – Use “CLASS A” PORTLAND CEMENT or approved equivalent.

5. Aggregates

c. Aggregates shall be well-graded, clean, hard particles or gravel or crushed rock conforming to the STANDARD SPECIFICATION FOR CONCRETE AGGREGATES (ASTM Designation C-33: latest revision).

d. Sand – ASTM C 35 – 67, clean, washed river sand, strong, free from organic and other deleterious materials. Sand from salt water is not allowed.

6. Water – Shall be clean and free from injurious amounts of oils, acids, alkali, organic materials or other deleterious substances.

ITEM (3.18): STRUCTURAL STEEL , METAL STRUCTURES AND ACCESSORIES

Conform all materials and workmanship to the requirements of the American Institute of Steel Construction "Specifications for Design, Fabrication and Erection of Structural Steel for Buildings" as amended to date or as may be specifically modified by the drawings or by these Specifications.

Welding shall be performed by the metal-arc process, using the electrodes specified with either direct or alternating current. Conform all materials and workmanship to the requirements of the American Institute of Steel Construction "Specifications for Design, Fabrication and Erection of Structural Steel for Buildings" as amended to date or as may be specifically modified by the drawings or by these Specifications. Welding of Structural Steel shall be done only when shown on the Plans or authorized in writing by the Engineer.

Surfaces to be welded shall be smooth, uniform and free from fins, tears, and other defects which would adversely affect the quality of the weld. Edges of material shall be trimmed by machining, chipping, grinding, or machine gas-cutting to produce a satisfactory welding edge wherever such edge is thicker than: 13 mm for sheared edge of material; 16 mm for toes of angles or rolled shapes (other than wide flange sections); 25 mm for universal mill plate or edges of flange sections.

No operation or actual welding or gas-cutting shall be performed on a member while it is carrying live load stress or while subject to shock and vibration and from moving loads. Welding and gas-cutting shall cease in advance of the application of such loads.

Plates, Sheets, Flange and Connectors: Conform to ASTM Designation A36 with specified yield point of 248 Mpa (36,000 psi). From mild steel sheets or plates with standard thickness, size, shape and design as indicated in the plans. For miscellaneous stiffener, bearing anchorage and connector plates or straps. Upgrade to next higher / bigger size and thickness if specified sizes & thicknesses are unavailable.

Standard solid section: Conform to ASTM 611 with specified yield point of 228 Mpa (33,000 psi). Mild steel angles, flat bars, square bars, channels, U and other sections. For purlins, building eaves framing, grill works, miscellaneous fabricated mounting brackets, straps, dowels, frames and connectors. Upgrade to next higher / bigger size and thickness if specified sizes & thickness are unavailable.

Bolt Accessories: Bolts, nuts circular washers shall conform to High-Strength Bolts for Structural Steel Joints, including Suitable Nuts and Plain Hardened Washer, AASHTO M 164 (ASTM A 325).

Fastenings - Commercial types, except where special types are shown or required. Fastenings for all exterior work shall be non-ferrous, unless otherwise shown. Fastening for stainless steel and aluminum and other interior work, where exposed shall match the fastened metal.

Angle bars, Purlins and Rectangular Tube: Conform to ASTM 611 with specified yield point of 228 Mpa (33,000 psi). Mild steel angles, flat bars, square bars, channels, U and other sections. For purlins, building eaves framing, grill works, miscellaneous fabricated mounting brackets, straps, dowels, frames and connectors. Refer to trusses and purlins schedule for thickness, size, shape and design. Refer to Sun-baffle schedule for rectangular tubing. Upgrade to next higher / bigger size and thickness if specified sizes & thicknesses are unavailable.

Welding Electrodes: Conform welding electrodes to ASTM Specification A233 and AWS Specification A5.1 and A5.5 E60 series for manual shielded metal arc welding and E-70 series for structural welding.

Painting: Use only approved brand of epoxy zinc chromate paint and linseed oil for all base coat painting for structural steel. For finish painting, use enamel paint or approved equal.

Metal Hangers - Use "CLASS A" or approved equal.

Brass Iron – 2" Ø pipe for **ramps and stairs**.

Stainless Steel - 2" Ø pipe for **CR grab bars**

Stair Nosing – use 2.5" x 2.5" stair nosing and must be welded to the stair dowels before concreting

No operation or actual welding or gas-cutting shall be performed on a member while it is carrying live load stress or while subject to shock and vibration and from moving loads. Welding and gas-cutting shall cease in advance of the application of such loads.

PROJECT CLOSE-OUT

Upon completion of the project, the following procedure shall be implemented:

4. Walk-thru inspection by the owner, engineer and contractor. Any discrepancy noted shall be fixed before the project is closed.
5. Compile a complete equipment maintenance manual for all equipment. Submit copy of "As-built" drawings to the owner and engineer.
6. Construction Logbook with complete data (template will be provided by DSWD) must be submitted to the owner/engineer.

*****END OF SPECIFICATIONS*****

Section VI. Specifications

LOT 3:

REPAIR OF REGIONAL HAVEN FOR WOMEN FOR WOMEN ADMIN BUILDING ROOFING, FLOORING, OLD ODRMITORY MAIN DOOR, IMPROVEMENT OF VENTILATION AND CONCRETING OF RAMP

ITEM 1: GENERAL REQUIREMENTS

RELATED SECTIONS

All applicable provisions of the different divisions of the Specifications for each work trade shall apply for all items cited in this Summary.

INFERRED ITEMS AND WORK

Materials and workmanship deemed necessary to complete the works but NOT specifically mentioned in the Specifications, Working Drawings, or in the other Contract Documents, shall be supplied and installed by the Contractor without extra cost to the Owner. Such materials shall be of the highest quality available, and installed or applied in a workmanlike manner at prescribed or appropriate locations.

SPECIFICS

Materials specifically mentioned in this Summary shall be installed following efficient and sound engineering and construction practice, and especially as per manufacturer's application for installation specifications which shall govern all works alluded to in these Specifications.

ON-SITE ITEMS

Materials and finishes for on-site improvements and facilities as listed below are part of the scope of work and shall be supplied and installed by the Contractor without extra cost to the Owner.

E. Construction of:

7. Walks, ramps, steps, posts, perimeter fence and miscellaneous slabs;
8. Concrete catch basins, drainage pipes;
9. Temporary facilities and below grade structures such as septic vaults, cisterns, manholes, open canals, check drains and trenches;

- F. Exterior utility lines, raceway system, fixtures, breakers, switches, buzzers, controls including fittings and accessories as required by the specialty trades under plumbing, mechanical and electrical works.

OFF-SITE ITEMS

Off-site improvements shall generally be under the responsibility of the Owner and not included in the Contract, with the exception of the following which shall be part of the Contractor's Work:

Construction of drainage lines. This work shall neatly connect to the storm drainage system along the road. Permanent connections to the local utility lines for electrical, water, drainage, sewer and telephone lines including equipment, facilities, materials, fees, and/or work which utility companies or authorities may require of the applicant Owner, such as electrical transformers, etc.

WATER & ELECTRICITY CONNECTION

- E. Temporary Water: The Contractor shall supply in sufficient quantity all necessary potable and other water for construction purposes for all trades at a point within a reasonable distance of the building being constructed. The Contractor shall make arrangements and pay charges for water service installation, maintenance, and removal thereof, and pay the costs of water for all trades.
- F. Temporary Electricity: The Contractor shall make all necessary arrangements for a temporary electrical service, pay all expenses in connection with the installation, operation and removal thereof, and pay the costs of electricity consumed by all trades.

OWNER SUPPLIED ITEMS

Owner supplied finishing accessories, furnishing and fixtures such as wall clocks, picture frames, fixed furniture etc., shall be installed by the Contractor at no cost to the Owner.

QUALITY CONTROL

The Contractor shall be responsible for the quality control of all materials during the handling, blending, and mixing and placement operations. The Contractor shall furnish the Engineer a Quality Control Plan detailing his production control procedures and the type and frequency of sampling and testing to insure that the materials and work produces complies with the Specifications. The Engineer shall be provided free access to recent plant production records, and if requested, informational copies of mix design, materials certifications and sampling and testing reports.

The Contractor shall perform all sampling, testing and inspection necessary to assure quality control of the component materials.

ITEM (1.1): PROJECT BILLBOARD/SIGNBOARD

Project Billboards/COA signages shall be installed near the construction site or before the entrance gate and must be visible for the visitors.

Signage sizes: **Project Signage = 4ft. x 8ft.**
 COA Signage = 8ft. x 8ft.

ITEM (1.3): TEMPORARY FENCE

The whole area affected for the project shall be fenced temporarily with necessary gates as directed by the Engineer. The site must be closed enough and must not be visible for the clients living in the center.

ITEM II: CLEARING

ITEM (3.1): REMOVAL OF STRUCTURES AND OBSTRUCTION

Existing structures shall be removed and cleared in preparation for new construction. The Contractor shall make arrangements with the Center Head/owner for the items needed and not needed for disposal. The Contractor shall be responsible for the disposal of the waste materials from the demolished structure.

ITEM III: ROOFING AND TILEWORKS

ITEM (3.2 & 3.3): METAL ROOFING SHEETS, FLASHINGS, GUTTER AND ACCESSORIES

Pre-formed Metal Roofing: Use “CLASS A” Oven-baked, Pre-painted G.I. Long Span Hi-Rib, 0.6mm thick with complete accessories. Submit sample for Engineer’s approval.

Use “CLASS A”, Oven Baked, Ridge rolls and vent, flashings, cappings, gutters, trims, and mouldings: 0.6 mm thick (Preformed).

Strainer: Use “CLASS A” Brass Dome Strainers or Stainless Steel leaf strainer. Submit sample for Engineer’s approval.

Fasteners and Fixation: Use appropriate connectors as recommended by the manufacturer and approved by the Architect. Paint same color as roof, all exposed fixation and fastening devices. Apply fasteners in a neat, consistent, even and standard manner. Apply strip of butyl rubber-based caulking compound along all end lap joints and passing over pre-drilled fixation holes. For fixation of metal sheet

to “C” purlins and when lapped over another metal sheet. For fixation of flashing. Use Tek screws for roof eaves area, where roof frames are exposed.

Sealants: “CLASS A” Sealants shall be used in areas necessary to render structure watertight, sufficient even during strong winds:

ITEM (3.4): TILES

Use glazed tile for walls and unglazed tile for floors. Tiles must be soak to water for atleast 3 hours before installation. Refer to schedule of tiles.

7. **Mortar:** Use Portland Cement or any approved equivalent.
8. **Sand:** ASTM C 35 – 67, clean, washed river sand, strong, free from organic and other deleterious materials. Sand from salt water or lahar is not allowed.
9. **Water:** Fit for drinking, free from injurious amount of oil, acids, alkali, organic materials and other deleterious substances.
10. **Adhesive Mortar:** Use “CLASS A” for laying vitrified ceramic tiled.
11. **Grout:** Use “Class A” pre-mixed dry wall filler for floor and wall tile either glazed or semi-glazed tiles. Masonry concrete grout compressive strength (f_c') = 13.8 Mpa (2000 psi).
12. **Plaster Bond:** Use “Class A” or approved equal. Apply on all wall areas, as required, prior to plastering. Suppliers shall furnish product description prior to purchase and delivery.

ITEM (3.5): POLYCARBONATE SHEETS

Use 4.5mm thick solid Polycarbonate Sheet for main entrance roofing. Refer to schedule.

ITEM IV. VENTILATION (OLD DORMITORY)

ITEM (4.1) AIRCONDITIONING

This section includes installation of air-conditioning units with complete accessories. All materials whether specifically mentioned or not in the technical plan, but necessary to complete this item of work shall be furnished and installed in the best workmanship practice. All materials used shall be of high standard quality.

Air-conditioning Units:

3HP Wall Mounted, Split type, inverter

All items shall be installed with vibrator insulator, angle brace, with complete accessories.

ITEM V. RAMP

ITEM (5.1) EMBANKMENT & COMPACTION

Only coarse-grained fill materials shall be used inside buildings and under walkways, either limestone or diorite.

Fine-grained fill material, such as silt, clay, silty clay or clayey silt shall be laboratory approved from offsite source passing a 0.425 mm (no. 40) sieve and shall have a liquid limit not less than 40% and a plasticity index not less than 11%. Only fine grained fill material shall be used outside the limits of the buildings, for landscape purposes. Top soil stripped from the construction site may be stock piled and used for landscaping purposes as long as it is enriched to sustain landscape planting material.

Excavated material approved for use as backfill shall be free of stones larger than 2 inches in longest dimension, roots and organic materials.

The Contractor shall compact the material placed in all embankment layers and the material scarified to the designated depth below subgrade in cut sections, until a uniform density of not less than 95 mass percent of the maximum dry density is attained.

At least one group of three in-situ density tests shall be carried out for each 500 m of each layer of compacted fill. The layer shall be placed not exceeding 200 mm in loose measurement or based on the result of compacted trials.

ITEM (5.2): STRUCTURAL CONCRETE (CLASS A, 14 DAYS)

CEMENT – Use “CLASS A” PORTLAND CEMENT or approved equivalent.

CONCRETE AGGREGATES

4. Gravel: Well graded, clean, hard particles of gravel or crushed rock conforming to the “STANDARD SPECIFICATIONS FOR CONCRETE AGGREGATES” (ASTM Designated C-33 latest revision). Use 25 mm (1”) maximum for slabs and 19 mm (3/4”) for columns and beams and retaining walls.
5. Sand: ASTM C 35 – 67, clean, washed river sand, strong, free from organic and other deleterious materials. Sand from salt water or lahar is not allowed.
6. Maximum size of aggregates shall not be larger than 1/5 of the narrowest dimension between sides of the forms, not larger than 3/5 of the maximum clear spacing between reinforcing bars, and in no case larger than 33 mm (1-1/3”) in diameter.

WATER - Use only water that is clean and free from injurious amounts of oils, acids, alkali, organic materials or other deleterious substances. Potable/ fit for human consumption.

CONCRETE MIXES

Concrete compressive strength (f'_c) requirements:

I. Specified Compressive Strength			
Class/Type	14 days		Item
	psi	mPa	
A	3000	28	For footings, columns, beams, lintels beam and stiffener columns, slab on grade and for all reinforced work not otherwise indicated or specified
B	1,500	10.34	For all concrete without reinforcement like lean concrete

Slump requirements:

Structural Element	Slump for vibrated concrete	
	Minimum	Maximum
Slab on grade, stair landing and tread	75 mm	125 mm
Other components	50 mm	100 mm

CONCRETE ADDITIVES

8. Use "CLASS A" in the amounts as recommended by the manufacturer, with the approval of the Architect.
9. Plasticizer – Use "CLASS A"
10. Air-entraining admixtures – Use "CLASS A" or approved equal to improve workability or durability of concrete mixes.
11. Accelerators – Use "CLASS A" or approved equal.
12. Water Reducing Retarders – Use "CLASS A" or approved equal.
13. Integral Waterproofing Compound – Use "CLASS A" or approved equal for roof slabs, balcony, concrete gutters, cisterns and media aguas. Refer to Manufacturer's manual/instruction for proper application.
14. Calcium chloride is not allowed. Secure approval of the Engineer prior to using of any other additive.

NOTE: PLACEMENT DRAWINGS: Shop drawings of each reinforcing steel detail and placement drawings shall be submitted for approval in accordance with the requirements of the General Conditions. Any material fabricated before final approval of the shop drawings will be done at Contractor's risk, but no material shall be placed until shop drawings have final approval. Shop drawings shall be in accordance with the "Manual of Standard Practice for Detailing Reinforced Concrete Structures" (ACI 315).

ITEM (2.2): REINFORCING STEEL (DEFORMED, GRADE 40)

Steel Bars – Use structural grade ASTM A615 Grade 40 for deformed bars 12mmØ and below. For 16mmØ and above, use structural grade ASTM 615 Grade 60. Deformed bars shall be new and free from rust, oil, grease, defects or kinks. Upgrade to next bigger size if specified standard sizes are unavailable.

Use **Ga.16 Galvanized Iron (G.I.)** tie wires at joints or laps of placed reinforcements.

Steel reinforcement shall be stored above the surface of the ground upon platforms, skids, or other supports and shall be protected as far as practicable from mechanical injury and surface deterioration caused by exposure to conditions producing rust. Distance from the forms shall be maintained by means of stays, blocks, ties, hangers, or other approved supports, so that it does not vary from the position indicated on the Plans. Reinforcement in any member shall be placed and then inspected and approved by the Engineer before the placing of concrete begins. Concrete placed in violation of this provision may be rejected and removal may be required.

Splices: Splices shall be staggered as far as possible and with a minimum separation of not less than 40 bar diameters. Lapped splices will not be permitted at locations where the concrete section is insufficient to provide minimum clear distance of one and one-third the maximum size of coarse aggregate between the splice and the nearest adjacent bar.

ITEM (5.6): STEEL GRATING

Steel Bars – Use structural grade flat bars for steel grating. Steel bars shall be new and free from rust, oil, grease.

Surfaces to be welded shall be smooth, uniform and free from fins, tears, and other defects which would adversely affect the quality of the weld. Edges of material shall be trimmed by machining, chipping, grinding, or machine gas-cutting to produce a satisfactory welding edge wherever such edge is thicker than: 13 mm for sheared edge of material; 16 mm for toes of angles or rolled shapes (other than wide flange sections); 25 mm for universal mill plate or edges of flange sections.

CLEANING-UP

The contractor shall at all times keep the construction area, including storage areas used by him, free from accumulations of waste materials or rubbish and prior to completion of work. Remove any rubbish from and about the premises and all tools, scaffolding, equipment and materials not the property of the owner.

Upon the completion of the construction, the contractor shall leave the work and premises in a condition satisfactory to the owner and the engineer.

PROJECT CLOSE-OUT

Upon completion of the project, the following procedure shall be implemented:

7. Walk-thru inspection by the owner, engineer and contractor. Any discrepancy noted shall be fixed before the project is closed.
8. Compile a complete equipment maintenance manual for all equipment. Submit copy of "As-built" drawings to the owner and engineer.
9. Construction Logbook with complete data (template will be provided by DSWD) must be submitted to the owner/engineer.

*****END OF SPECIFICATIONS*****

Section VI. Specifications

LOT 4:

REPAIR OF GOME FOR GIRLS COVERED COURT ROOFING, CEILING AND PSCB BUILDING STORAGE DOOR AND MAIN DOOR

ITEM 1: GENERAL REQUIREMENTS

RELATED SECTIONS

All applicable provisions of the different divisions of the Specifications for each work trade shall apply for all items cited in this Summary.

INFERRED ITEMS AND WORK

Materials and workmanship deemed necessary to complete the works but NOT specifically mentioned in the Specifications, Working Drawings, or in the other Contract Documents, shall be supplied and installed by the Contractor without extra cost to the Owner. Such materials shall be of the highest quality available, and installed or applied in a workmanlike manner at prescribed or appropriate locations.

SPECIFICS

Materials specifically mentioned in this Summary shall be installed following efficient and sound engineering and construction practice, and especially as per manufacturer's application for installation specifications which shall govern all works alluded to in these Specifications.

ON-SITE ITEMS

Materials and finishes for on-site improvements and facilities as listed below are part of the scope of work and shall be supplied and installed by the Contractor without extra cost to the Owner.

G. Construction of:

10. Walks, ramps, steps, posts, perimeter fence and miscellaneous slabs;
11. Concrete catch basins, drainage pipes;
12. Temporary facilities and below grade structures such as septic vaults, cisterns, manholes, open canals, check drains and trenches;

- H. Exterior utility lines, raceway system, fixtures, breakers, switches, buzzers, controls including fittings and accessories as required by the specialty trades under plumbing, mechanical and electrical works.

OFF-SITE ITEMS

Off-site improvements shall generally be under the responsibility of the Owner and not included in the Contract, with the exception of the following which shall be part of the Contractor's Work:

Construction of drainage lines. This work shall neatly connect to the storm drainage system along the road. Permanent connections to the local utility lines for electrical, water, drainage, sewer and telephone lines including equipment, facilities, materials, fees, and/or work which utility companies or authorities may require of the applicant Owner, such as electrical transformers, etc.

WATER & ELECTRICITY CONNECTION

- G. Temporary Water: The Contractor shall supply in sufficient quantity all necessary potable and other water for construction purposes for all trades at a point within a reasonable distance of the building being constructed. The Contractor shall make arrangements and pay charges for water service installation, maintenance, and removal thereof, and pay the costs of water for all trades.
- H. Temporary Electricity: The Contractor shall make all necessary arrangements for a temporary electrical service, pay all expenses in connection with the installation, operation and removal thereof, and pay the costs of electricity consumed by all trades.

OWNER SUPPLIED ITEMS

Owner supplied finishing accessories, furnishing and fixtures such as wall clocks, picture frames, fixed furniture etc., shall be installed by the Contractor at no cost to the Owner.

QUALITY CONTROL

The Contractor shall be responsible for the quality control of all materials during the handling, blending, and mixing and placement operations. The Contractor shall furnish the Engineer a Quality Control Plan detailing his production control procedures and the type and frequency of sampling and testing to insure that the materials and work produces complies with the Specifications. The Engineer shall be provided free access to recent plant production records, and if requested, informational copies of mix design, materials certifications and sampling and testing reports.

The Contractor shall perform all sampling, testing and inspection necessary to assure quality control of the component materials.

ITEM (1.1): PROJECT BILLBOARD/SIGNBOARD

Project Billboards/COA signages shall be installed near the construction site or before the entrance gate and must be visible for the visitors.

Signage sizes: **Project Signage = 4ft. x 8ft.**
 COA Signage = 8ft. x 8ft.

ITEM (1.3): TEMPORARY FENCE

The whole area affected for the project shall be fenced temporarily with necessary gates as directed by the Engineer. The site must be closed enough and must not be visible for the clients living in the center.

ITEM II : CIVIL/FINISHING/ STRUCTURAL WORKS

ITEM (2.1): REMOVAL OF STRUCTURES AND OBSTRUCTION

Existing structures shall be removed and cleared in preparation for new construction. The Contractor shall make arrangements with the Center Head/owner for the items needed and not needed for disposal. The Contractor shall be responsible for the disposal of the waste materials from the demolished structure.

ITEM (2.2): SCAFFOLDINGS

The Contractor shall be responsible for the quality control & stability of all scaffoldings to be used in the project.

ITEM (3.3): CEILING AND FACIA BOARD (FIBER CEMENT)

14. **Fiber Cement Board:** Use "CLASS A", Install as per manufacturer's instructions. 6mm thick for all suspended ceilings and 19mm for facia board. See drawing details for Suspended Ceiling and facia board.
15. **Suspended Ceiling System:** Use 25mm x 50mm x 0.6mm thk metal furring, 12mmØ suspension rod, suspension clips, eyelets, attached to ceiling framing.
16. **Ceiling Framing:** Use 2" x 4" x 1.2mm thk. C-Purlins painted with anti-rust as carrying channel. C-Purlins must be welded properly to the wall angle (2" x 2" x 6mm thk. Angle bar).
17. **Wall Angle:** Use 2" x 2" x 6mm thk. Angle Bar bolted to the wall at every 0.6m.
18. Provide edgings, trims and moldings and others as indicated in the drawings.
19. **Hardware and Fasteners:** Use metal nails, screws, bolts, plates, straps, miscellaneous fasteners or anchorage concealed or countersunk whenever

called for, with size, shape and type to ensure a rigid connection for laminated items and at other framing joints.

ITEM (2.4 & 2.5): METAL ROOFING SHEETS, FLASHINGS, GUTTER AND ACCESSORIES

Pre-formed Metal Roofing: Use “CLASS A” Oven-baked, Pre-painted G.I. Long Span Hi-Rib, 0.6mm thick with complete accessories. Submit sample for Engineer’s approval.

Use “CLASS A”, Oven Baked, Ridge rolls and vent, flashings, cappings, gutters, trims, and mouldings: 0.6 mm thick (Preformed).

Strainer: Use “CLASS A” Brass Dome Strainers or Stainless Steel leaf strainer. Submit sample for Engineer’s approval.

Fasteners and Fixation: Use appropriate connectors as recommended by the manufacturer and approved by the Architect. Paint same color as roof, all exposed fixation and fastening devices. Apply fasteners in a neat, consistent, even and standard manner. Apply strip of butyl rubber-based caulking compound along all end lap joints and passing over pre-drilled fixation holes. For fixation of metal sheet to “C” purlins and when lapped over another metal sheet. For fixation of flashing. Use Tek screws for roof eaves area, where roof frames are exposed.

Sealants: “CLASS A” Sealants shall be used in areas necessary to render structure watertight, sufficient even during strong winds:

ITEM (3.16): PAINTINGS (CEMENT, WOOD AND METAL)

All paint and paint materials called for under this section shall be as manufactured by known manufacturer or owner approved equivalent and must be LEAD-FREE Paint. Use CLASS A only (one brand all throughout). All exposed finish hardware, lighting fixtures and accessories, plumbing fixtures and accessories, glasses and the like shall be adequately protected that these areas are not stained with paint and other painting materials prior to painting works. All other surfaces which would be endangered by stains or paint marks should be taped and covered with craft paper or equal.

Exterior: Use “CLASS A” paint PLAIN FINISH for all exterior finishes and as shown in the drawings and for all exposed and/or visible concrete and masonry surfaces, as well as for exterior HARDIFLEX surfaces unless otherwise specified.

Surface Preparation: Concrete and masonry surfaces must be fully cured for at least 14 days.

1st coat: Use Class A Concrete Primer And Sealer (as manufacturer instruction)

2nd coat: Use Class A Putty

3rd and 4th coats: Use Class A Concrete Primer and Sealer

Interior: USE "CLASS A" SKIM COAT PLAIN FINISH for minor interior walls indicated in the drawings and for all interior concrete and masonry surfaces unless otherwise specified.

Surface Preparation: Concrete and masonry surfaces must be fully cured for at least 14 days.

Metal Surfaces: Use "CLASS A" Liquid Tile. For ferrous surfaces such as steel and roof framing and other exposed steel surfaces unless otherwise specified.

Surface Preparation: Must be free from rust.

1st coat: Use CLASS A Primer Red Oxide

2nd and 3rd coats: Use CLASS A Aqua Gloss-It

Use only approved brand of epoxy zinc chromate paint and linseed oil for all base coat painting for structural steel. For finish painting, use enamel paint or approved equal.

Color codes for DSWD Facilities:

Interior Walls	:	Seed Pearl color
Exterior Walls	:	Dapper Tan Color
Baseboards	:	Shrimp Pink/Chocolate brown
Wooden Doors & Jambs	:	Wood Stain (One-way application)
Ceiling	:	Plain White

ITEM (2.8): STRUCTURAL STEEL, METAL STRUCTURES AND ACCESSORIES

Conform all materials and workmanship to the requirements of the American Institute of Steel Construction "Specifications for Design, Fabrication and Erection of Structural Steel for Buildings" as amended to date or as may be specifically modified by the drawings or by these Specifications.

Welding shall be performed by the metal-arc process, using the electrodes specified with either direct or alternating current. Conform all materials and workmanship to the requirements of the American Institute of Steel Construction "Specifications for Design, Fabrication and Erection of Structural Steel for Buildings" as amended to date or as may be specifically modified by the drawings or by these Specifications. Welding of Structural Steel shall be done only when shown on the Plans or authorized in writing by the Engineer.

Surfaces to be welded shall be smooth, uniform and free from fins, tears, and other defects which would adversely affect the quality of the weld. Edges of material shall be trimmed by machining, chipping, grinding, or machine gas-cutting to

produce a satisfactory welding edge wherever such edge is thicker than: 13 mm for sheared edge of material; 16 mm for toes of angles or rolled shapes (other than wide flange sections); 25 mm for universal mill plate or edges of flange sections.

No operation or actual welding or gas-cutting shall be performed on a member while it is carrying live load stress or while subject to shock and vibration and from moving loads. Welding and gas-cutting shall cease in advance of the application of such loads.

Plates, Sheets, Flange and Connectors: Conform to ASTM Designation A36 with specified yield point of 248 Mpa (36,000 psi). From mild steel sheets or plates with standard thickness, size, shape and design as indicated in the plans. For miscellaneous stiffener, bearing anchorage and connector plates or straps. Upgrade to next higher / bigger size and thickness if specified sizes & thicknesses are unavailable.

Standard solid section: Conform to ASTM 611 with specified yield point of 228 Mpa (33,000 psi). Mild steel angles, flat bars, square bars, channels, U and other sections. For purlins, building eaves framing, grill works, miscellaneous fabricated mounting brackets, straps, dowels, frames and connectors. Upgrade to next higher / bigger size and thickness if specified sizes & thickness are unavailable.

Bolt Accessories: Bolts, nuts circular washers shall conform to High-Strength Bolts for Structural Steel Joints, including Suitable Nuts and Plain Hardened Washer, AASHTO M 164 (ASTM A 325).

Fastenings - Commercial types, except where special types are shown or required. Fastenings for all exterior work shall be non-ferrous, unless otherwise shown. Fastening for stainless steel and aluminum and other interior work, where exposed shall match the fastened metal.

Angle bars, Purlins and Rectangular Tube: Conform to ASTM 611 with specified yield point of 228 Mpa (33,000 psi). Mild steel angles, flat bars, square bars, channels, U and other sections. For purlins, building eaves framing, grill works, miscellaneous fabricated mounting brackets, straps, dowels, frames and connectors. Refer to trusses and purlins schedule for thickness, size, shape and design. Refer to Sun-baffle schedule for rectangular tubing. Upgrade to next higher / bigger size and thickness if specified sizes & thicknesses are unavailable.

Welding Electrodes: Conform welding electrodes to ASTM Specification A233 and AWS Specification A5.1 and A5.5 E60 series for manual shielded metal arc welding and E-70 series for structural welding.

Painting: Use only approved brand of epoxy zinc chromate paint and linseed oil for all base coat painting for structural steel. For finish painting, use enamel paint or approved equal.

Metal Hangers - Use "CLASS A" or approved equal.

Brass Iron – 2" Ø pipe for **ramps and stairs**.

Stainless Steel - 2" Ø pipe for **CR grab bars**

Stair Nosing – use 2.5" x 2.5" stair nosing and must be welded to the stair dowels before concreting

No operation or actual welding or gas-cutting shall be performed on a member while it is carrying live load stress or while subject to shock and vibration and from moving loads. Welding and gas-cutting shall cease in advance of the application of such loads.

ITEM (2.10): TEMPERED GLASS

MAIN DOOR: Use 12mm thk. Tempered Bronze Glass Door, swing type with, frameless with 38mm dia. Stainless steel 304 door handle.

SLIDING DOOR: Use 6mm thk. Tempered Bronze Glass Sling Door on aluminum frame

CLEANING-UP

The contractor shall at all times keep the construction area, including storage areas used by him, free from accumulations of waste materials or rubbish and prior to completion of work. Remove any rubbish from and about the premises and all tools, scaffolding, equipment and materials not the property of the owner.

Upon the completion of the construction, the contractor shall leave the work and premises in a condition satisfactory to the owner and the engineer.

PROJECT CLOSE-OUT

Upon completion of the project, the following procedure shall be implemented:

10. Walk-thru inspection by the owner, engineer and contractor. Any discrepancy noted shall be fixed before the project is closed.
11. Compile a complete equipment maintenance manual for all equipment. Submit copy of "As-built" drawings to the owner and engineer.
12. Construction Logbook with complete data (template will be provided by DSWD) must be submitted to the owner/engineer.

*****END OF SPECIFICATIONS*****

Section VII. Drawings

[Insert here a list of Drawings. The actual Drawings, including site plans, should be attached to this section, or annexed in a separate folder – OF EACH LOTS]

Section VIII. Bill of Quantities

LOT 1: REPAIR OF AVRC II WING I, WING III AND WING IV ROOFING, CEILING & ROOM PARTITIONS					
ITEM NO.	DESCRIPTION	QUANTITY	UNIT	UNIT COST	TOTAL
I. GENERAL REQUIREMENTS					
1.1	Project Billboard/Signboard	1.00	each		
1.2	Mobilization and Demobilization	1.00	L.S.		
1.3	Temporary Fence and storage rooms	1.00	L.S.		
Sub-Total					-
II. PLAIN AND REINFORCEMENT CONCRETE WORKS					
2.1	Structural Concrete (Class A, 28 days)	0.59	cu.m.		
2.2	Reinforcing Steel (Deformed. Grade 40)	229.00	kg.		
2.3	Formworks, Falseworks & Scaffoldings	14.00	sq.m.		
Sub-Total					-
III. CIVIL / FINISHING WORKS					
3.1	Removal and Disposal of Affected Structures and Obstruction	1.00	L.S.		
3.2	Plumbing Works (sanitary, waterline & vents)	1.00	L.S.		
3.3	Ceiling, 6mm Fiber Cement Board with Metal Frame spaced @0.4m x0.4m O.C. with 16mm diameter Plain bar vertical support with threaded lock	1,305.00	sq.m.		
3.4	Ceiling Vent, wood frame,1” x 1” Good lumber with insect screen, (collapsible at every 1.2 meter)	738.00	bd.ft.		
3.5	Fascia Board, 12mm Fiber Cement Board	130.00	l.m.		
3.6	Frames, Jambs, including installation of 5 units viewing glass, 6mm thick	1.00	set		

ITEM NO.	DESCRIPTION	QUANTITY	UNIT	UNIT COST	TOTAL
3.7	Doors, Solid Door with jambs, hinges and in stain paint finish (3-sets, 1m x 2.1m)	6.30	sq.m.		
3.8	Door, Solid Door with viewing glass, jambs, hinges and in stain paint finish (1-set, 1m x 2.1m)	2.10	sq.m.		
3.9	Tempered Glass - 1 set, 1m x 2.1m x 12mm thick Bronze glass door - 1 set, 1.3m x 1.4m x 12mm thick One Way Mirror	3.92	sq.m.		
3.10	Fabricated Metal Roofing Accessories, gauge 24, flashings, Oven baked	484.00	L.m.		
3.11	Fabricated Metal roofing Accessories, gauge 24, valley rolls/gutter, Over baked	36.60	L.m.		
3.12	Oven Baked Prepainted Metal Sheets, 0.6mm thick Rib Type, Long Span with 10mm thick, Insulation foam laid on screen matting	643.00	sq.m.		
3.13	Waterproofing (Cement base)	69.00	sq.m.		
3.14	Glazed Tiles and Trims	45.00	sq.m.		
3.15	Cement Plaster Finish	100.00	sq.m.		
3.16	Painting Works (concrete, masonry, wood, steel)	2,647.00	sq.m.		
3.17	CHB (including Reinforcing Steel) 150mm	50.00	sq.m.		
3.18	Structural Steel 1.5" x 1.5" x 6mm thick Angle Bar 2" x 2" x 6mm thick Angle Bar 2" x 4" x 1.2mm thick C-Purlins 2" x 4" x 1.2mm thick C-Purlins (Ceiling Frame) 0.3m x 0.3m x 12mm thick Steel Plate 0.15m x 0.15m x 6mm thick Steel Plate 12mm dia. x 6m def. (sag rod & bracket) 12mm dia. x 6m def. bar (cross bracing)	17,854.00	kg.		
3.19	Metal Structures and Accessories – Bolts	184.00	pc.		

ITEM NO.	DESCRIPTION	QUANTITY	UNIT	UNIT COST	TOTAL
3.20	Metal Strictures and Accessories – Tumbuckle	36.00	pc.		
3.21	Aluminum Louver, Air Ventilation & Sun Baffle with 2” x 2” x 2mm thick tube framing	1.00	L.S.		
3.22	Installation of cushioned floor carpet	11.76	sq.m.		
3.23	Installation of Wall Cushion	29.66	sq.m.		
Sub-Total					-
IV. ELECTRICAL					
4.1	Conduits, Boxes and Fittings	1.00	L.S.		
4.2	Wires and Wiring Devices	1.00	L.S.		
4.3	Lightning Fixtures	1.00	L.S.		
Sub-Total					
VI. MECHANICAL WORKS					
6	Air conditioning, 3hp, wall mounted, inverter, split type (including restoration of electrical line)	2.00	set		
Sub-Total					-
TOTAL CONTRACT COST				-	

Section VIII. Bill of Quantities

LOT 2: REPAIR OF AVRC II COVERED COURT ROOFING, CEILING AND STAGE WALL					
ITEM NO.	DESCRIPTION	QUANTITY	UNIT	UNIT COST	TOTAL
I. GENERAL REQUIREMENTS					
1.1	Project Billboard/Signboard	1.00	Lot		
1.2	Mobilization and Demobilization	1.00	L.S.		
1.3	Temporary Fence and storage rooms	1.00	L.S.		
Sub-Total					-
II. CIVIL / FINISHING / STRUCTURAL WORKS					
2.1	Removal and Disposal of Affected Structures and Obstruction	1.00	L.S.		
2.2	Scaffoldings, including construction safety and health	1.00	L.S.		
2.3	Ceiling, 6mm Fiber Cement Board with Metal Frame spaced @0.4m x0.4m O.C.	56.00	sq.m.		
2.4	Wall, 6mm Fiber cement Board (double wall) with metal frame spaced at 0.4m x 0.4m O.C.	76.00	sq.m.		
2.5	Fabricated Metal Roofing Accessories, gauge 24, flashings	50.00	L.m.		
2.6	Fabricated Metal Roofing Accessories, gauge 24, valley rolls / gutter	77.00	L.m.		
2.7	Oven Baked Prepainted Metal Sheets, 0.6mm thick Rib Type, Long Span with 10mm thick, Insulation foam laid on screen matting -including sealing of roof holes and screwing of partially detached roofing	75.00	sq.m.		
2.8	Painting Works (Masonry / Concrete)	208.00	sq.m.		
2.9	Painting Works (Steel)	69.00	sq.m.		

ITEM NO.	DESCRIPTION	QUANTITY	UNIT	UNIT COST	TOTAL
2.10	Structural Steel <ul style="list-style-type: none"> • 29 lengths 2" x 2" x 2mm thick Square tube for stage wall framing • 6 lengths 2" x 2" x 6mm thick Angle Bar for Ceiling wall angle • 6 lengths 2" x 2" x 6mm thick Angle Bar for flashing clip • 4 lengths 2" x 4" C-Purlins for Ceiling framing 	1,153.05	kg.		
Sub-Total					-
TOTAL CONTRACT COST				-	

Section VIII. Bill of Quantities

LOT 3: REPAIR AND IMPROVEMENT OF REGIONAL HAVEN FOR WOMEN ADMIN BUILDING ROOFING, FLOORING, OLD DORMITORY MAIN DOOR, IMPROVEMENT OF VENTILATION AND CONCRETING OF RAMP

ITEM NO.	DESCRIPTION	QUANTITY	UNIT	UNIT COST	TOTAL
I. GENERAL REQUIREMENTS					
1.1	Project Billboard/Signboard	1.00	L.S		
1.2	Mobilization and Demobilization	1.00	L.S.		
1.3	Temporary Fence and storage rooms	1.00	L.S.		
Sub-Total					-
II. CLEARING					
2.1	Removal and Disposal of Affected Structures and Obstruction	1.00	L.S.		
Sub-Total					-
III. ROOFING AND TILEWORKS WORKS					
3.1	Tempered Glass Door, 12mm thick, swing type, frameless with stainless door handle	4.20	sq.m.		
3.2	Fabricated Metal Roofing Accessories, gauge 24, flashings, pre-painted including sealing od roof holes	74.00	L.m.		
3.3	Fabricated Metal Roofing Accessories, gauge 24, valley rolls / gutter, pre-painted	22.00	L.m.		
3.4	Tiles, 0.6m x 0.6m granite tiles	220.00	sq.m.		
3.5	Solid Polycarbonate Sheets, 4.5mm thick Bronze color	20.88	l.m.		
Sub-Total					-
IV. VENTILATION (OLD DORMITORY)					
4.1	Air conditioning, 3hp, Wall Mounted, Split Type Inverter	2.00	set		
Sub-Total					-

ITEM NO.	DESCRIPTION	QUANTITY	UNIT	UNIT COST	TOTAL
V. RAMP					
5.1	Embankment & Compaction	4.00	cu.m.		
5.2	Structural Concrete (Class A, 14 days)	3.00	cu.m.		
5.3	Reinforcing Steel (Deformed, Grade 60)	70.00	kg.		
5.4	Catch Basin (CHB)	2.00	Each		
5.5	Painting Works (Steel)	3.00	sq.m		
5.6	Steel Gratin, (catch basins & linear gratings)	1.00	L.S.		
Sub-Total					-
TOTAL CONTRACT COST				-	

Section VIII. Bill of Quantities

LOT 4: REPAIR OF HOME FOR GIRLS (HFG) COURT ROOFING, CEILING AND PSCB BUILDING STORAGE DOOR AND MAIN DOOR					
ITEM NO.	DESCRIPTION	QUANTITY	UNIT	UNIT COST	TOTAL
I. GENERAL REQUIREMENTS					
1.1	Project Billboard/Signboard	1.00	Lot		
1.2	Mobilization and Demobilization	1.00	L.S.		
1.3	Temporary Fence and storage rooms	1.00	L.S.		
Sub-Total					-
II. CIVIL / FINISHING / STRUCTURAL WORKS					
2.1	Removal and Disposal of Affected Structures and Obstruction	1.00	L.S.		
2.2	Scaffoldings, including construction safety and health	1.00	L.S.		
2.3	Ceiling, 6mm Fiber Cement Board with Metal Frame spaced @0.4m x0.4m O.C.	56.00	sq.m.		
2.4	Fabricated Metal Roofing Accessories, gauge 24, flashings	25.00	L.m.		
2.5	Oven Baked Prepainted Metal Sheets, 0.6mm thick Rib Type, Long Span with 10mm thick, Insulation foam laid on screen matting -including sealing of roof holes and screwing of partially detached roofing	100.00	sq.m.		
2.6	Painting Works (Masonry / Concrete)	846.00	sq.m.		
2.7	Painting Works (Steel)	16.00	sq.m.		
2.8	Structural Steel <ul style="list-style-type: none"> • 6 lengths 2" x 2" x 6mm thick Angle Bar for Ceiling wall angle • 6 lengths 2" x 2" x 6mm thick Angle Bar for flashing clip • 4 lengths 2" x 4" C-Purlins for Ceiling framing 	318.21	kg.		

ITEM NO.	DESCRIPTION	QUANTITY	UNIT	UNIT COST	TOTAL
2.9	Clearing of gutter, including installation of stainless steel leaf guard	1.00	Lot		
2.10	Supply and Installation of Tempered Sliding Glass Door, 6mm thick on aluminum frame and 12mm thick Tempered Bronze glass, swing door, aluminum frame with lock & stainless handle	1.00	set		
2.11	Troubleshooting of grounded wires, including drying of wet wires and embedded pipes	1.00	L.S.		
Sub-Total					-
TOTAL CONTRACT COST				-	

Section IX. Checklist of Technical and Financial Documents

I. TECHNICAL COMPONENT ENVELOPE

Class “A” Documents

Legal Documents

- (a) Valid PhilGEPS Registration Certificate (Platinum Membership) (all pages);
and
- (b) Registration certificate from Securities and Exchange Commission (SEC), Department of Trade and Industry (DTI) for sole proprietorship, or Cooperative Development Authority (CDA) for cooperatives or its equivalent document;
and
- (c) Mayor’s or Business permit issued by the city or municipality where the principal place of business of the prospective bidder is located, or the equivalent document for Exclusive Economic Zones or Areas;
and
- (e) Tax clearance per E.O. No. 398, s. 2005, as finally reviewed and approved by the Bureau of Internal Revenue (BIR).

Technical Documents

- (f) Statement of the prospective bidder of all its ongoing government and private contracts, including contracts awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid; **and**
- (g) Statement of the bidder’s Single Largest Completed Contract (SLCC) similar to the contract to be bid, except under conditions provided under the rules; **and**

NOTE: This statement shall be supported with:

- i) Either of Contract, Purchase Order, Notice of Award or Notice to Proceed; and
 - ii) Either of Certificate of Completion, Certificate of Acceptance, Inspection and Acceptance, Official Receipt/Collection Receipt or Sales Invoice.
- (h) Philippine Contractors Accreditation Board (PCAB) License;
or
Special PCAB License in case of Joint Ventures;
and registration for the type and cost of the contract to be bid; **and**
 - (i) Original copy of Bid Security. If in the form of a Surety Bond, submit also a certification issued by the Insurance Commission;
or
Original copy of Notarized Bid Securing Declaration; **and**

- (j) Project Requirements, which shall include the following:
 - a. Organizational chart for the contract to be bid;
 - b. List of contractor's key personnel (e.g., Project Manager, Project Engineers, Materials Engineers, Safety Officer and Foremen), to be assigned to the contract to be bid, with their complete qualification and experience data;
 - c. List of contractor's major equipment units, which are owned, leased, and/or under purchase agreements, supported by proof of ownership or certification of availability of equipment from the equipment lessor/vendor for the duration of the project, as the case may be;
 - d. **Certificate of Site Inspection signed by the Head of the Procuring Entity (HoPE) or its authorized representative;**
Additional contract documents relevant to the Project that may be required by existing laws and/or the Procuring Entity, such as:
 - e. ***construction schedule and S-curve,***
 - f. ***manpower schedule,***
 - g. ***construction methods,***
 - h. ***equipment utilization schedule,***
 - i. ***construction safety and health program signed by the contractor, and***
- (k) Original duly signed Omnibus Sworn Statement (OSS);
and if applicable, Original Notarized Secretary's Certificate in case of a corporation, partnership, or cooperative; or Original Special Power of Attorney of all members of the joint venture giving full power and authority to its officer to sign the OSS and do acts to represent the Bidder.

Financial Documents

- (l) The prospective bidder's audited financial statements, showing, among others, the prospective bidder's total and current assets and liabilities, stamped "received" by the BIR or its duly accredited and authorized institutions, for the preceding calendar year which should not be earlier than two (2) years from the date of bid submission;
and
- (m) The prospective bidder's computation of Net Financial Contracting Capacity (NFCC); **or**
A committed Line of Credit from a Universal or Commercial Bank in lieu of its NFCC computation.
- (n) Supplier must have an existing Landbank of the Philippines (LBP) Account in compliance to DBM Circular Letter No. 2013-16. This shall be verified during the conduct of post-qualification.

Class "B" Documents

- (o) If applicable, duly signed joint venture agreement (JVA) in accordance with RA No. 4566 and its IRR in case the joint venture is already in existence; **or**
duly notarized statements from all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful.

II. FINANCIAL COMPONENT ENVELOPE

- (p) Original of duly signed and accomplished Financial Bid Form; **and**

Other documentary requirements under RA No. 9184

- (q) Original duly signed Bid Prices in the Bill of Quantities; **and**
- (r) Duly accomplished Detailed Estimates Form
- (s) Summary sheet indicating the unit prices of construction materials, labor rates and equipment rentals used in coming up with the Bid; **and**
- (t) Cash Flow by Quarter or Monthly.

Section X. BIDDING FORMS

Omnibus Sworn Statement

Project Identification No. ITB No. DSWD7-PB-2022-44

REPUBLIC OF THE PHILIPPINES)
CITY/MUNICIPALITY OF _____) S.S.

AFFIDAVIT

I, [Name of Affiant], of legal age, [Civil Status], [Nationality], and residing at [Address of Affiant], after having been duly sworn in accordance with law, do hereby depose and state that:

1. *[Select one, delete the other:]*

[If a sole proprietorship:] I am the sole proprietor or authorized representative of [Name of Bidder] with office address at [address of Bidder];

[If a partnership, corporation, cooperative, or joint venture:] I am the duly authorized and designated representative of [Name of Bidder] with office address at [address of Bidder];

2. *[Select one, delete the other:]*

[If a sole proprietorship:] As the owner and sole proprietor, or authorized representative of [Name of Bidder], I have full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for [Name of the Project] of the [Name of the Procuring Entity], as shown in the attached duly notarized Special Power of Attorney;

[If a partnership, corporation, cooperative, or joint venture:] I am granted full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for [Name of the Project] of the [Name of the Procuring Entity], as shown in the attached [state title of attached document showing proof of authorization (e.g., duly notarized Secretary's Certificate, Board/Partnership Resolution, or Special Power of Attorney, whichever is applicable)];

3. [Name of Bidder] is not "blacklisted" or barred from bidding by the Government of the Philippines or any of its agencies, offices, corporations, or Local Government Units, foreign government/foreign or international financing institution whose blacklisting rules have been recognized by the Government Procurement Policy Board, **by itself or by relation, membership, association, affiliation, or controlling interest with another blacklisted person or entity as defined and provided for in the Uniform Guidelines on Blacklisting;**
4. Each of the documents submitted in satisfaction of the bidding requirements is an authentic copy of the original, complete, and all statements and information provided therein are true and correct;
5. [Name of Bidder] is authorizing the Head of the Procuring Entity or its duly authorized representative(s) to verify all the documents submitted;
6. *[Select one, delete the rest:]*

[If a sole proprietorship:] The owner or sole proprietor is not related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

[If a partnership or cooperative:] None of the officers and members of [Name of Bidder] is related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

[If a corporation or joint venture:] None of the officers, directors, and controlling stockholders of [Name of Bidder] is related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

7. [Name of Bidder] complies with existing labor laws and standards; and
8. [Name of Bidder] is aware of and has undertaken the responsibilities as a Bidder in compliance with the Philippine Bidding Documents, which includes:

- a. Carefully examining all of the Bidding Documents;
 - b. Acknowledging all conditions, local or otherwise, affecting the implementation of the Contract;
 - c. Making an estimate of the facilities available and needed for the contract to be bid, if any; and
 - d. Inquiring or securing Supplemental/Bid Bulletin(s) issued for the *[Name of the Project]*.
9. *[Name of Bidder]* did not give or pay directly or indirectly, any commission, amount, fee, or any form of consideration, pecuniary or otherwise, to any person or official, personnel or representative of the government in relation to any procurement project or activity.
10. **In case advance payment was made or given, failure to perform or deliver any of the obligations and undertakings in the contract shall be sufficient grounds to constitute criminal liability for Swindling (Estafa) or the commission of fraud with unfaithfulness or abuse of confidence through misappropriating or converting any payment received by a person or entity under an obligation involving the duty to deliver certain goods or services, to the prejudice of the public and the government of the Philippines pursuant to Article 315 of Act No. 3815 s. 1930, as amended, or the Revised Penal Code.**

IN WITNESS WHEREOF, I have hereunto set my hand this ___ day of ___, 20__ at _____, Philippines.

[Insert NAME OF BIDDER OR ITS AUTHORIZED REPRESENTATIVE]

[Insert signatory's legal capacity]
Affiant

[Jurat]

[Format shall be based on the latest Rules on Notarial Practice]

Republic of the Philippines)
In the City of _____) s.s

SECRETARY CERTIFICATE

I, _____, of legal age, single/married, Filipino citizen, resident of _____ City, after having been duly sworn in accordance with law, hereby certify:

1. That I am the duly designated Corporate Secretary of _____, a corporation duly organized and existing under and virtue of the laws of the Republic of the Philippines, with principal address at _____ City.
2. That at the special meeting of the Board of Directors at its principal office on _____ 2021, during which a quorum was present and acted throughout, the following resolution was unanimously approved:

“Resolution No. 2021- xxx

RESOLVED, that _____ of legal age, single/married, resident of _____ is hereby authorized to appear, participate, bid, transact, contract, agree, communicate, correspond, sign, receive documents and receipts for and in behalf of _____ (corporation), in the bidding/contract/agreement with DSWD Field Office VII.”

3. That the foregoing resolution has not been altered, modified, nor revoked; and that the same is now in full force and in effect; and

This is to certify that the foregoing Board Resolution duly passed and approved, is true and correct.

IN WITNESS WHEREOF, I have hereunto set my hand on this _____ day of _____, 2021 at _____ City, Philippines

Corporate Secretary

SUBSCRIBED AND SWORN to before me this _____ day of _____ 2021, at _____, Philippines. Affiant exhibited to me his/her (government issued ID), issued at _____, on _____.

Notary Public

Doc No. _____
Page No. _____
Book No. _____
Series of 2021

REPUBLIC OF THE PHILIPPINES)
CITY OF _____) S.S.

BID SECURING DECLARATION
Project Identification No.: ITB No. DSWD7-PB-2022-44

To: *[Insert name and address of the Procuring Entity]*

I/We, the undersigned, declare that:

1. I/We understand that, according to your conditions, bids must be supported by a Bid Security, which may be in the form of a Bid Securing Declaration.
2. I/We accept that: (a) I/we will be automatically disqualified from bidding for any procurement contract with any procuring entity for a period of two (2) years upon receipt of your Blacklisting Order; and, (b) I/we will pay the applicable fine provided under Section 6 of the Guidelines on the

Use of Bid Securing Declaration, within fifteen (15) days from receipt of the written demand by the procuring entity for the commission of acts resulting to the enforcement of the bid securing declaration under Sections 23.1(b), 34.2, 40.1 and 69.1, except 69.1(f), of the IRR of RA No. 9184; without prejudice to other legal action the government may undertake.

3. I/We understand that this Bid Securing Declaration shall cease to be valid on the following circumstances:
- Upon expiration of the bid validity period, or any extension thereof pursuant to your request;
 - I am/we are declared ineligible or post-disqualified upon receipt of your notice to such effect, and (i) I/we failed to timely file a request for reconsideration or (ii) I/we filed a waiver to avail of said right; and
 - I am/we are declared the bidder with the Lowest Calculated Responsive Bid, and I/we have furnished the performance security and signed the Contract.

IN WITNESS WHEREOF, I/We have hereunto set my/our hand/s this ____ day of [month] [year] at [place of execution].

[Insert NAME OF BIDDER OR ITS AUTHORIZED REPRESENTATIVE]

[Insert signatory's legal capacity]
Affiant

[Jurat]

[Format shall be based on the latest Rules on Notarial Practice]

BID FORM

Date : _____

Project Identification No.: **ITB No. DSWD7-2022-44**

To: *[name and address of Procuring Entity]*

Having examined the Philippine Bidding Documents (PBDs) including the Supplemental or Bid Bulletin Numbers *[insert numbers]*, the receipt of which is hereby duly acknowledged, we, the undersigned, declare that:

- We have no reservation to the PBDs, including the Supplemental or Bid Bulletins, for the Procurement Project: *[insert name of contract]*;
- We offer to execute the Works for this Contract in accordance with the PBDs;
- The total price of our Bid in words and figures, excluding any discounts offered below is: *[insert information]*;
- The discounts offered and the methodology for their application are: *[insert information]*;

- e. The total bid price includes the cost of all taxes, such as, but not limited to: *[specify the applicable taxes, e.g. (i) value added tax (VAT), (ii) income tax, (iii) local taxes, and (iv) other fiscal levies and duties]*, which are itemized herein and reflected in the detailed estimates,
- f. Our Bid shall be valid within the a period stated in the PBDs, and it shall remain binding upon us at any time before the expiration of that period;
- g. If our Bid is accepted, we commit to obtain a Performance Security in the amount of *[insert percentage amount]* percent of the Contract Price for the due performance of the Contract, or a Performance Securing Declaration in lieu of the allowable forms of Performance Security, subject to the terms and conditions of issued GPPB guidelines¹ for this purpose;
- h. We are not participating, as Bidders, in more than one Bid in this bidding process, other than alternative offers in accordance with the Bidding Documents;
- i. We understand that this Bid, together with your written acceptance thereof included in your notification of award, shall constitute a binding contract between us, until a formal Contract is prepared and executed; and
- j. We understand that you are not bound to accept the Lowest Calculated Bid or any other Bid that you may receive.
- k. We likewise certify/confirm that the undersigned, is the duly authorized representative of the bidder, and granted full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for the [Name of Project] of the [Name of the Procuring Entity].
- l. We acknowledge that failure to sign each and every page of this Bid Form, including the Bill of Quantities, shall be a ground for the rejection of our bid.

Name: _____

Legal Capacity: _____

Signature: _____

Duly authorized to sign the Bid for and behalf of: _____

Date: _____

¹ currently based on GPPB Resolution No. 09-2020

SUPPLIER / SERVICE PROVIDER'S BANK INFORMATION

Name of Bank	
Branch	
Bank Account Name	
Account No.	
TIN No.	

PLEASE CHECK IF TIN NUMBER is VAT or NON-VAT

VAT

☐

**NON-
VAT**

☐

Signature:

Name of Authorized Representative:

Position:
